



**BID BULLETIN NO. 01**  
**CILO 2021-022**  
**October 1, 2021**

**Bid Bulletin No. 01 CILO 2021-022** is hereby issued for the information of Prospective Bidders relative to the bidding for the project **CONCRETING OF BASE OF MET SENSOR MAST INCLUDING FABRICATION OF SCAFFOLDINGS AT ILOILO INTERNATIONAL AIRPORT.**

A. The Additional Description/Specifications of the following items shall be:

	Items	Unit	Qty	Additional Specifications
	<b>Materials</b>			
	I. Supply, Delivery and Fabrication of Movable 15 ft high Scaffold Tower 10 ft Bay			
1.0	Supply, Delivery and Fabrication of 5'x5' 1 1/2" Sch 20 GI Pipe H-frames 10' angle iron brace 19 x 10 Steel head AP walk-boards Scaffoldings	set	1	
	Specifications include (6) 5' X 5' 1" Masonry (Step) Frames; (6) Angle BRA103648H Angle Iron 10' Cross Braces; (12) 7" Coupling Pins; (12) Spring Clips; (12) Toggle (hinge) Pins; Full Top Deck Guard Rail System; (3) All Aluminum 10' Walkboards; (4) Leveling Screw Jacks; and Powder Coated Finish.			Leveling adjuster will be used on the feet of the fabricated stand not necessarily on the total height
	II. Concrete Works for Base of MET Sensor (4mx4mx6"thick sloping concrete base) including Excavation and Steel Works	sq.M	16	
	Portland Cement	bag	23	
	Gravel	cu.m	3	
	Washed Sand	cu.m	2	
	10mm diameter Reinforcement Steel Bar	pcs	12	Reinforcement Steel bar is 10mm in diameter and has a spacing of .50 m in both ways
	No. 16 G.I. Tie Wire	kg	1	



Republic of the Philippines  
CIVIL AVIATION AUTHORITY OF THE PHILIPPINES

Scope of Work:			
• Supply, Delivery and Fabrication of 15 ft high 5'x5' 1 1/2" Sch 20 GI Pipe H- frames 10' angle iron brace 19 x 10 Steel head AP walk-boards with Powder Coated Finish Scaffoldings			GI Pipe Members of Scaffoldings could be non-powder coated finish
• Excavation Works			
• Steel Works (Matting)			
• Concreting Works for Base of MET Sensor (4mx4mx6"thick sloping concrete base)			
• Clearing of the Working Area			

B. Duration of the Project shall be changed from **15 Calendar Days to 30 Calendar Days**.

C. All sealed envelopes must contain the Mode of Procurement: **NEGOTIATED PROCUREMENT** and/or **COMPETITIVE BIDDING** for the project. Failure to comply with this requirement will be a ground for disqualification.

D. The CAAP-BAC reserves the right to reject any or all bids, to waive defects or formality therein and to accept bids considered responsive and most advantageous to the Government.

**ATTY. FRANCES SHANELLE G. SALINAS**  
BAC Chairperson