



Republic of the Philippines
CIVIL AVIATION AUTHORITY OF THE PHILIPPINES

BID BULLETIN NO. 02

October 28, 2019

- I.** Attention is hereby invited to the Bidders of **Procurement of Air-Conditioning System at Bacolod (Silay) Airport – Bid No. 19-050-09 Bravo.**
- II.** Please be informed of the following issues/clarifications:

Issues/Queries	Clarification/s
1. Do we strictly adhere to the efficiency of at least 1.045KW/TR at 100% load as specified or is it possible to offer unit with efficiency of 1.246KW/TR at 100% load?	1. The chiller energy efficiency is changed from 1.045KW/TR at 100% load to 1.4 KW/TR at 100% load or better. Hence, efficiency of 1.246KW/TR at 100% load is acceptable.

For the information and guidance of all concerned.


ATTY. JOSEPH RAY P. GUMABON
Chairperson, Bids and Awards Committee - Bravo