



SUPPLEMENTAL / BID BULLETIN No.5  
**SUPPLY/DELIVERY/INSTALLATION OF BACK-UP GENSET  
3P, 750KVA, 460V and ACCESSORIES AT CENTRAL OFFICE CAAP  
COMPOUND, PASAY CITY**  
(Bid No. 20-005-02 ALPHA)


03 June 2020

I. Please note the following amendments / revisions to the bidding documents:

Reference	Remarks	Additional Requirement /Specification
Schedule of Requirement	For Info	<b>Manual Transfer Switch</b> 1250AT, 3Φ, 460V, 80ka, NEMA 1 free standing, change over switch type.
Bill of Quantities	To be included in the BOQ	Under Item No.3 Supply/Installation of One (1) unit 1250AT, 3Φ, 460V, 80ka, NEMA 1 Free Standing, Manual Transfer Switch, Change Over switch type.
Technical Specifications Item No.13	For info	<b>WARRANTY</b> CAAP requires One (1) year warranty for the whole project. Include in your bid proposal the Maintenance program (parts & service) of the Generator set during the warranty period.
Technical Specifications Item No.2	For info	<b>GENERATOR ENCLOSURE</b> Enclosure shall be factory assembled, sound proof with 85dB at 5 meters minimum complete with standard accessories, exhaust silencer with flexible bellow.

II. This Bid Bulletin shall be an integral part of the Bidding Documents and the same shall be enclosed in the technical bid envelope / component and shall be marked / tabbed accordingly.

For the information and guidance of all concerned.

  
**CAPTAIN DONALDO A. MENDOZA**  
Chairman, Bids and Awards Committee

*aml*