



SUPPLEMENTAL / BID BULLETIN NO. 01

**PURCHASE/INSTALLATION OF DVOR/DME for BICOL INTERNATIONAL AIRPORT**  
(Bid No. 20-004-11 Delta)

03 December 2020

- I. Please note the following amendments/ revisions/ clarifications to the Bidding Documents:

| Reference  | Remarks                             | Requirement/ Specification   |
|--|-------------------------------------|--|
| 8.5. Step-up/Step Down Distribution Transformers shall be 15KVA, 1 Ø Phase, 240/2400V oil-immersed, self-cooled. Fuse cut outs and Lightning Arrester combinations and accessories shall be rated for the purpose. | Additional information/ requirement | 8.5. Step-up/Step Down Distribution Transformers shall be 15KVA, 1-Ø Phase, 60Hz, 400V/2400V; 2400V/240V, oil-immersed, self-cooled. Fuse cut outs and Lightning Arrester combinations and accessories shall be rated for the purpose.   |
| Reference Drawings   | Additional information/ requirement | Composed of Six (6) pages titled with the following:<br>01/11 Vicinity map<br>04/11 FOC/Electrical Cable Layout from DVOR/DME going to Powerhouse<br>07/11 Single Line Diagram<br>08/11 Transformer Installation Details<br>09/11 Transformer Yard<br>10/11 Transformer Cage Details |

This bid bulletin shall be an integral part of the Bidding Documents and the same shall be enclosed in the technical bid envelop/component and shall be marked/tabbed accordingly.

Bids not complying with the above instructions shall be disqualified.

For the information and guidance of all concerned.

  
**CAPTAIN DONALDO A. MENDOZA**  
Chairman, Bids and Awards Committee-Delta