



BID BULLETIN NO. 1


23 February 2022

I. Attention is hereby invited to the Bidders of the project **Consultancy Services for the Conduct of Detailed Engineering Design of the Expansion of Passenger Terminal Building (PTB) Davao International Airport - Bid No. 19-056-11 Bravo**

II. Please be informed of the following issues/clarifications:

Issues / Queries	Clarification/s
1. Whether the winning consultant is required to design the Common Use Terminal Equipment (CUTE) considering that these are owned by SITA?	Yes. The winning consultant is required to submit a schematic and layout plan for roughing-ins and other necessary works, including electrical and IT works, in anticipation of the installation and provision of Common Use Terminal Equipment (CUTE) in the expansion area of the PTB.
2. Whether the Clean Agent Fire Suppression System is necessary to be included in the design?	Yes. This is in compliance with the Fire Code of the Philippines and indicated in the Terms of Reference that the Clean Agent Fire Suppression System must be included in the design. Should the winning consultant intend to introduce an equal alternative fire suppression system, it must be reviewed and approved by the Project Management Office.
3. What is the Bid Validity Period?	One hundred twenty (120) days from opening of the bids in accordance with Section 28 of the Revised Implementing Rules and Regulations of RA No. 9184.
<i>nothing follows</i>	

For the information and guidance of all concerned.


CAPTAIN DONALDO A. MENDOZA
Chairperson
Bids and Awards Committee – Bravo