



**BID BULLETIN NO. 01**  
**CILO 2022-013**  
**AUGUST 12, 2022**

**Bid Bulletin No. 01 CILO 2022-013** is hereby issued for the information of Prospective Bidders relative to the bidding for the project **REPAIR AND MAINTENANCE OF LIGHTING SYSTEM AT ILOILO INTERNATIONAL AIRPORT.**

A. The Additional/Corrected Description/Specifications of the following items shall be:

Item No.	Items	Unit	Qty	Specifications
1.0	<b>Integrated Solar Street Lights 80 Watts</b>	4	pc	<ul style="list-style-type: none"><li>• Luminous Flux output: 8000lm</li><li>• Light Source Power: 80 W</li><li>• LED Chip: USA Bridgelux</li><li>• Infrared Motion Sensor</li><li>• Auto ON at night time and OFF at day time</li><li>• Light Color: Warm White</li><li>• Battery: High Efficiency Lithium Iron Phosphate</li><li>• IP Grade: IP65 Outdoor</li><li>• Visual Angle: 120°</li><li>• Charge Time: 9-10 Hours</li><li>• Work Time: 10 Hr Full Power 20 Hr Saving Mode</li><li>• Work Temperature: 0-60°</li><li>• Materials: Aluminum Alloy and Toughened Glass</li><li>• Solar Panel: 18VDC, 80 Watts</li><li>• Net Weight 16 kg or less</li><li>• Installation Height: 7m</li><li>• Warranty: 3 years</li></ul>
2.0	<b>Integrated Solar Street Lights 10 Watts</b>	13	pcs	<ul style="list-style-type: none"><li>• Luminous Flux output: 1000lm</li></ul>



				<ul style="list-style-type: none"><li>• Light Source Power: 10W</li><li>• LED Chip: USA Bridgelux</li><li>• Infrared Motion Sensor</li><li>• Auto ON at night time and OFF at day time</li><li>• Light Color: Day Light</li><li>• Battery: High efficiency Lithium Iron Phosphate</li><li>• IP Grade: IP65 Outdoor</li><li>• Visual Angle: 120°</li><li>• Charge Time: 9-10 Hours</li><li>• Work Time: 10 Hr Full Power 20 Hr Saving Mode</li><li>• Work Temperature: 0-60°</li><li>• Materials: Aluminum Alloy and Toughened Glass</li><li>• Solar Panel: 18VDC, 12 Watts</li><li>• Net Weight 5 kg or less</li><li>• Installation Height: 2-3 m</li><li>Warranty: 3 years</li></ul>
6.0	Panel Light 36 watts, 595mm x 595 mm	30	sets	Must be Powder Coated finish

B. All sealed envelopes must contain the Mode of Procurement: **COMPETITIVE BIDDING** for the project. Failure to comply with this requirement will be a ground for disqualification.

C. The CAAP-BAC reserves the right to reject any or all bids, to waive defects or formality therein and to accept bids considered responsive and most advantageous to the Government.

  
**ATTY. FRANCES SHANELLE G. SALINAS**  
BAC Chairperson