



Republic of the Philippines
CIVIL AVIATION AUTHORITY OF THE PHILIPPINES

SUPPLEMENTAL/BID BULLETIN NO. 23-01

MARCH 7, 2023

This supplemental/bid bulletin is issued to clarify, modify or amend items in the Bidding Documents for the project: Supply, Delivery and Installation of 100KVA Single Phase DEGS at Francisco B. Reyes "Busuanga" Airport with Identification Number **23-02-02**.

SECTION/CLAUSES AFFECTED	QUERY/CONCERN	AMMENDMENTS/ CLARIFICATIONS/RESPONSES
A. Invitation to Bid ❖ Item #11	a. For hard copy, one original and one copy of the first and second components of its bid. Three-envelope system.	a. For hard copy, one original and two (2) copies of the first and second components of its bid. Three-envelope system.
B. Section III. Bid Data Sheet ❖ ITB Clause 15	a. For hard copy, one original and one copy of the first and second components of its bid. Three envelope system.	a. For hard copy, one original and two (2) copies of the first and second components of its bid. Three envelope system.
C. Other Concerns	It is stated in the technical specification the length of wire. How will the wires be connected to the panel board? Will we provide cable tray?	There is an existing wire/cable duct being used by the 30kVA DEGS that may be utilized as per end user.
	May we know the size of the existing concrete pad where the 100kVA DEGS will be mounted on?	Please refer to Annex "A" for the dimensions provided by the End User.
	May we also know the dimensions of the radiator vent and exhaust pipe size?	Please refer to Annex "A" for the dimensions provided by the End User. Additional works may be needed should said dimensions be under sized.

The foregoing shall form as an integral part of the Bidding Documents. Any provision/s in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance of all concerned.


ENGR. ROWLAND G. ALARCON
 Chairperson, Bids and Awards Committee
 CAAP AREA CENTER IV – PPIA

Annex A

