



SUPPLEMENTAL BID BULLETIN NO. 24-01
24 April 2024

This Supplemental Bid Bulletin is issued to clarify, modify, or amend items in the Bidding Document for the project: **“Procurement of Air Cooled Screw Chiller Auxfan Motor”** at **Puerto Princesa International Airport** with **Identification Number 24-03-03**.

As published/downloaded to the PhilGEPS and CAAP Website;

Section VI. Schedule of Requirements

Item Number (Code)	Description	Quantity	Total	Delivered, Weeks/ Months
1060305 0 2312	PROCUREMENT OF AIR COOLED SCREW CHILLER AUXFAN MOTOR AT PUERTO PRINCESA INTERNATIONAL AIRPORT	1 LOT	PhP1,800,000.00	30 Calendar Days upon receipt of the NTP.
	Air Coled Screw Chiller Auxfan Motor	10 Units		
	Specifications:			
	*Variable Voltage 380 Volts – 575 Volts 3 Phase 60 Hz			
	*Chiller Reference: Cooling Capacity : 910 kw Power Input ; 298.6 kw COP : 3 Chi. Water Temp. : 12/7°C Fluid Flow Rate : 156.6 m3/h REF. / Charge : 134a/240 kg			
	xxxxxx			

I hereby verify to comply with all the above requirements.

Signature over the printed name of the authorized representative

Company name

Date

Section VII. Technical Specifications

Item (Code)	Specification	Statement of Compliance
10603050 2312	<p>PROCUREMENT OF AIR COOLED SCREW CHILLER AUXFAN MOTOR AT PUERTO PRINCESA INTERNATIONAL AIRPORT</p> <p>Air Coled Screw Chiller Auxfan Motor Specifications: Variable Voltage 380 Volts – 575 Volts 3 Phase 60 Hz *Chiller Reference:</p> <p>Cooling Capacity : 910 kw Power Input ; 298.6 kw COP : 3 Chi. Water Temp. : 12/7°C Fluid Flow Rate : 156.6 m3/h REF. / Charge : 134a/240 kg</p>	<p><i>[Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder’s statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]</i></p>

I hereby verify to comply with all the above requirements.

Signature over the printed name of the authorized representative

Company name

Date

For Amendment:

Section VI. Schedule of Requirements

Item Number (Code)	Description	Quantity	Total	Delivered, Weeks/ Months
1060305 0 2312	PROCUREMENT OF AIR COOLED SCREW CHILLER AUXFAN MOTOR AT PUERTO PRINCESA INTERNATIONAL AIRPORT	1 LOT	PhP1,800,000.00	30 Calendar Days upon receipt of the NTP.
	Air Cooled Screw Chiller Auxfan Motor	10 Units		
	<i>Specifications:</i>			
	*Variable Voltage 380 Volts – 575 Volts 3 Phase 60 Hz			
	*Chiller Reference: Cooling Capacity : 910 kw Power Input ; 298.6 kw COP : 3 Chi. Water Temp. : 12/7°C Fluid Flow Rate : 156.6 m3/h REF. / Charge : 134a/240 kg			
	xxxxxx			

I hereby verify to comply with all the above requirements.

Signature over the printed name of the authorized representative

Company name

Date

Section VII. Technical Specifications

Item (Code)	Specification	Statement of Compliance
10603050 2312	<p>PROCUREMENT OF AIR COOLED SCREW CHILLER AUXFAN MOTOR AT PUERTO PRINCESA INTERNATIONAL AIRPORT</p> <p>Air Cooled Screw Chiller Auxfan Motor Specifications: Variable Voltage 380 Volts – 575 Volts 3 Phase 60 Hz *Chiller Reference:</p> <p>Cooling Capacity : 910 kw Power Input ; 298.6 kw COP : 3 Chi. Water Temp. : 12/7°C Fluid Flow Rate : 156.6 m3/h REF. / Charge : 134a/240 kg</p>	<p><i>[Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder’s statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]</i></p>

I hereby verify to comply with all the above requirements.

Signature over the printed name of the authorized representative

Company name

Date

The foregoing shall form as an integral part of the Bidding Document. Any provision in the Bidding Document inconsistent herewith is hereby amended, modified and superseded accordingly.

Other Matters:

- The **“No Contact Rule”** shall be strictly observed. Bidders are not allowed to call or talk to any member of the Bids and Awards Committee, Technical Working Group or Secretariat right after the opening of bids.
- The **CIVIL AVIATION AUTHORITY OF THE PHILIPPINES - BIDS AND AWARDS COMMITTEE AREA CENTER IV, PUERTO PRINCESA INTERNATIONAL AIRPORT (CAAP - BAC AREA CENTER IV, PPIA)** reserves the right to accept or reject any bid, and to annul the bidding process and to reject all bids at any time prior to contract award, without thereby incurring liability to the affected bidder/bidders.

For the guidance of all concerned.



ADAMOR J. PAET

Chairperson, Bids and Awards Committee
CAAP BAC AREA CENTER IV - PPIA