



REQUEST FOR QUOTATION

The Civil Aviation Authority of the Philippines (CAAP-Main Office), through its Canvass and Contract Committee (CCC), will undertake a **Small Value Procurement** for the “Supply and delivery of 253 sets MV Power Cable Splicing Kits for various airports” in accordance with Section 53.9 of the Implementing Rules and Regulations of Republic Act No. 9184.

RFQ No. : **C24-040-05**
Name of Project : **Supply and delivery of 253 sets MV Power Cable Splicing Kits for various airports**
Approved Budget for Contract : **P885,500.00**
Terms : See the attached Annex “A” for Terms of Reference and corresponding Specifications
Location : Procurement Division, CAAP, MIA Road, Pasay City
Delivery Term : **One Hundred Twenty (120) calendar days** from the receipt of Notice for Compliance
Partial delivery is **not allowed**
Delivery Location : **ANS Logistic Office, CAAP**
Delivery Time : **8:00 AM – 4:00 PM**

Interested suppliers are required to submit their valid and current documents which must be properly fastened and sealed in an envelope:

1. Mayor’s or Business Permit issued by the city or municipality where the principal place of business of the prospective bidder is located, or the equivalent document for Exclusive Economic Zones or Areas;
2. Income Business Tax Return for ABC’s above P500,000.00;
3. PHILGEPS Certificate of Registration;
4. Tax Clearance;
5. Notarize Omnibus Sworn Statement (GPPB prescribed Form) for ABC’s above P50,000.00; (Authorized representative must attach Special Power of Attorney (SPA) for Sole Proprietorship Certificate for Corporation)
6. Price quotation from (**Annex “A”**) during submission of offer/Quotation.

The winning supplier shall – upon claiming of the Contract – present the original copy of the documents listed above for comparison, or submit a **Certified True Copy** of the original document which must be certified by the issuing government agency. However, the **original copy** of the Omnibus Sworn Statement, Price Quotation Form, and Brochure **must be included in the sealed bid**.

Price quotation/s must be valid for a period of one hundred twenty (120) calendar days from the date of submission.

The quotation shall be submitted in sealed envelope on or before the closing date of **MAY 17 2024** at 10:00 AM, CAAP Procurement Division and addressed to:

MELINA C. REYES
Vice-Chairperson, Canvass and Contract Committee
Gate 3 CAAP, Old MIA Road
Pasay City, Metro Manila




Quotations exceeding the Approved Budget for the Contract shall be rejected.

Award of contract shall be made to the lowest quotation, which complies with the minimum description as stated above and other terms and conditions stated in the price quotation form. In case two or more bidders are determined to have submitted the Lowest Calculated/Lowest Calculated and Responsive Quotation, CAAP-CCC shall adopt and employ "draw lots" as the tie breaking method to finally determine the single winning provider in accordance with GPPB Circular 06-2005.

The CAAP-TIAC shall have the right to inspect and/or test the goods to confirm their conformity to the technical specifications.

Any interlineations, erasures or overwriting shall be valid only if they are signed or initialed by the bidder or his/her duly authorized representative/s.

Liquidated damages equivalent to one tenth of one percent (0.1%) of the value of the goods not delivered within the prescribed delivery period shall be imposed per day of delay. CAAP shall rescind the contract once the cumulative amount of liquidated damaged reaches ten percent (10%) of the amount of the contract, without prejudice to other courses of action and remedies open to it.


MELINA C. REYES
CCC Vice-Chairperson



PRICE QUOTATION FORM

Date: _____

The Chairperson
 Canvass and Contract Committee
 Procurement Division, CAAP,
 MIA Road, Pasay City

Sir:

After having carefully read and accepted the terms and conditions in the Request for Quotation, hereunder is our quotation/s for the item/s as follows:

Supply and Delivery of 253 Sets MV Power Cable Splicing Kits for Various Airports				
Technical Specifications	QTY	Unit	Unit Price	Total Price
Medium Voltage Unshielded Power Cable In-line Splicing Kits Cable Size: 8.0 sq. mm copper Conductor OD: 5/8" maximum Voltage Rating: Up to 5,000 V Standard: UL listed for Direct Earth Burial and submerged application up to 90 deg. C Material: Resin Inclusion: Mold Body Pouring Spout Electrical Tape Resin Case	253	sets		
Total (Inclusive of VAT)				

Amount in words:

The above-quoted prices are inclusive of all costs and applicable taxes.

Additional Requirement/s:

1. Include free training to users on how to use the product for two (2) identical sessions.
2. Bid documents must be accompanied by a list of completed and on- going projects for the past five (5) years related to Supply of Electrical Parts, Consumables and Devices; and Electrical Installations and Maintenance
3. Warranty: Six (6) months



Very truly yours,

Name/Signature of Representative

Position

Name of Company

Contact No.

Email Address



TERMS OF REFERENCE

Name of Project	:	Supply and Delivery of 253 Sets MV Power Cable Splicing Kits for Various Airports
Approved Budget	:	Php 885,500.00
Delivery Period	:	One- hundred Twenty (120) calendar days from the receipt of Notice for Compliance <i>Note: Partial delivery is not allowed.</i>
Delivery Location	:	ANS Logistics Office, CAAP, Old Mia Road, Pasay City <i>Note: Delivery must be made only from 8:00AM-4:00PM during regular work days.</i> <i>A Written Notice must be sent to the official email address of the Procurement Division, and Supply Division at least seven (7) calendar days prior to the intended date of delivery.</i> <i>A confirmation of availability of concerned office must be received by the supplier before proceeding with the delivery. None compliance may be a ground for refusal of entry to the premises and receipt of delivery with no fault on the part of the Civil Aviation Authority of the Philippines.</i>
Terms of Payment	:	Payment upon acceptance of the end-user and subject to usual government accounting rules and regulations.

Technical Specifications:



Unit	Item Description	Quantity
sets	Medium Voltage Splicing Kit Conductor: 8.0 sq. mm, 5kV, Direct Earth Burial Connector: up to 5/8" OD Standard: UL listed for direct earth burial and submerged application up to 90 deg. C Material: Resin Inclusion in the Package: Mold Body Pouring Spout Electrical Tapes Resin Cast Instruction Manual Include free training to users in how to use the product for two (2) identical sessions, maximum of 15 participants per training	253



	Packaging: Packed with cushioning materials to prevent damage during mishandling	
--	--	--

Additional Requirements:

1. Technical datasheets and specifications from the manufacturer. Specifications must satisfy the requirements.
2. Bid documents must be accompanied by a list of completed and on- going projects for the past five (5) years related to Supply of Electrical Parts, Consumables and Devices; and Electrical Installations and Maintenance
3. Certificate of Warranty for six (6) months from the date of acknowledgement of receipt delivery

Prepared by:  ALBERT C. VELASCO <i>CNSSO IV, ANOD</i>	Approved by:  FLORIAN S. ATIENZA <i>Acting Department Manager III</i>
--	--