

Republic of the Philippines CIVIL AVIATION AUTHORITY OF THE PHILIPPINES

# PURCHASE/INSTALLATION OF PAPI SYSTEM AT SAN VICENTE AIRPORT

BID NO. 24-095-10 ALPHA

Date of Issue of Bid Docs

09 Oct 2024 (POSTING)

# TABLE OF CONTENTS

Glossary	y of Terms, Abbreviations, and Acronyms	4
Section 1	I. Invitation to Bid	4
Section 1	II. Instructions to Bidders	9
1.	Scope of Bid	10
2.	Funding Information	10
3.	Bidding Requirements	10
4.	Corrupt, Fraudulent, Collusive, Coercive, and Obstructive Practices	10
5.	Eligible Bidders	10
6.	Origin of Associated Goods	11
7.	Subcontracts	11
8.	Pre-Bid Conference	11
9.	Clarification and Amendment of Bidding Documents	11
10.	Documents Comprising the Bid: Eligibility and Technical Components	11
11.	Documents Comprising the Bid: Financial Component	12
12.	Alternative Bids	12
13.	Bid Prices	12
14.	Bid and Payment Currencies	13
15.	Bid Security	13
16.	Sealing and Marking of Bids	13
17.	Deadline for Submission of Bids	13
18.	Opening and Preliminary Examination of Bids	13
19.	Detailed Evaluation and Comparison of Bids	14
20.	Post Qualification	14
21.	Signing of the Contract	14
Section 1	III. Bid Data Sheet	15
Section 1	IV. General Conditions of Contract	19
1.	Scope of Contract	20
2.	Sectional Completion of Works	20
3.	Possession of Site	20
4.	The Contractor's Obligations	20

5.	Performance Security	.20	
6.	Site Investigation Reports	.21	
7.	Warranty	.21	
8.	Liability of the Contractor	.21	
9.	Termination for Other Causes	.21	
10.	Dayworks	.21	
11.	Program of Work	.21	
12.	Instructions, Inspections and Audits	.22	
13.	Advance Payment	.22	
14.	Progress Payments	.22	
15.	Operating and Maintenance Manuals	.22	
Section V	7. Special Conditions of Contract	.23	
Section V	/I. Specifications	.24	
Section V	/II. Drawings	.46	
Section VIII. Bill of Quantities			
Section IX. Checklist of Technical and Financial Documents			

# Glossary of Terms, Abbreviations, and Acronyms

**ABC** – Approved Budget for the Contract.

**ARCC** – Allowable Range of Contract Cost.

BAC – Bids and Awards Committee.

**Bid** – A signed offer or proposal to undertake a contract submitted by a bidder in response to and in consonance with the requirements of the bidding documents. Also referred to as *Proposal* and *Tender.* (2016 revised IRR, Section 5[c])

**Bidder** – Refers to a contractor, manufacturer, supplier, distributor and/or consultant who submits a bid in response to the requirements of the Bidding Documents. (2016 revised IRR, Section 5[d])

**Bidding Documents –** The documents issued by the Procuring Entity as the bases for bids, furnishing all information necessary for a prospective bidder to prepare a bid for the Goods, Infrastructure Projects, and/or Consulting Services required by the Procuring Entity. (2016 revised IRR, Section 5[e])

BIR - Bureau of Internal Revenue.

BSP – Bangko Sentral ng Pilipinas.

**CDA –** Cooperative Development Authority.

**Consulting Services** – Refer to services for Infrastructure Projects and other types of projects or activities of the GOP requiring adequate external technical and professional expertise that are beyond the capability and/or capacity of the GOP to undertake such as, but not limited to: (i) advisory and review services; (ii) pre-investment or feasibility studies; (iii) design; (iv) construction supervision; (v) management and related services; and (vi) other technical services or special studies. (2016 revised IRR, Section 5[i])

**Contract** – Refers to the agreement entered into between the Procuring Entity and the Supplier or Manufacturer or Distributor or Service Provider for procurement of Goods and Services; Contractor for Procurement of Infrastructure Projects; or Consultant or Consulting Firm for Procurement of Consulting Services; as the case may be, as recorded in the Contract Form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.

**Contractor** – is a natural or juridical entity whose proposal was accepted by the Procuring Entity and to whom the Contract to execute the Work was awarded. Contractor as used in these Bidding Documents may likewise refer to a supplier, distributor, manufacturer, or consultant.

**CPI –** Consumer Price Index.

**DOLE –** Department of Labor and Employment.

**DTI** – Department of Trade and Industry.

**Foreign-funded Procurement or Foreign-Assisted Project** – Refers to procurement whose funding source is from a foreign government, foreign or international financing institution as specified in the Treaty or International or Executive Agreement. (2016 revised IRR, Section 5[b]).

**GFI** – Government Financial Institution.

**GOCC** – Government-owned and/or –controlled corporation.

**Goods** – Refer to all items, supplies, materials and general support services, except Consulting Services and Infrastructure Projects, which may be needed in the transaction of public businesses or in the pursuit of any government undertaking, project or activity, whether in the nature of equipment, furniture, stationery, materials for construction, or personal property of any kind, including nonpersonal or contractual services such as the repair and maintenance of equipment and furniture, as well as trucking, hauling, janitorial, security, and related or analogous services, as well as procurement of materials and supplies provided by the Procuring Entity for such services. The term "related" or "analogous services" shall include, but is not limited to, lease or purchase of office space, media advertisements, health maintenance services, and other services essential to the operation of the Procuring Entity. (2016 revised IRR, Section 5[r])

**GOP** – Government of the Philippines.

**Infrastructure Projects** – Include the construction, improvement, rehabilitation, demolition, repair, restoration or maintenance of roads and bridges, railways, airports, seaports, communication facilities, civil works components of information technology projects, irrigation, flood control and drainage, water supply, sanitation, sewerage and solid waste management systems, shore protection, energy/power and electrification facilities, national buildings, school buildings, hospital buildings, and other related construction projects of the government. Also referred to as *civil works or works*. (2016 revised IRR, Section 5[u])

LGUs - Local Government Units.

**NFCC –** Net Financial Contracting Capacity.

- NGA National Government Agency.
- PCAB Philippine Contractors Accreditation Board.

**PhilGEPS -** Philippine Government Electronic Procurement System.

**Procurement Project** – refers to a specific or identified procurement covering goods, infrastructure project or consulting services. A Procurement Project shall be described, detailed, and scheduled in the Project Procurement Management Plan prepared by the agency which shall be consolidated in the procuring entity's Annual Procurement Plan. (GPPB Circular No. 06-2019 dated 17 July 2019)

- **PSA –** Philippine Statistics Authority.
- **SEC –** Securities and Exchange Commission.
- **SLCC –** Single Largest Completed Contract.
- **UN –** United Nations.

# Section I. Invitation to Bid



# Invitation to Bid for

# Purchase/Installation of PAPI System at San Vicente Airport

- The Civil Aviation Authority of the Philippines through the Corporate Operating Budget for CY 2024-2025 (MYBA) intends to apply the sum of Twenty-Five Million Seven Hundred Eighty-Three Thousand Five Hundred Ninety-Five Pesos and Twenty-Two Centavos (Php 25,783,595.22) being the Approved Budget for the Contract (ABC) to payments under the contract for Purchase/Installation of PAPI System at San Vicente Airport with Project Identification Number [BID NO. 24-095-10 ALPHA]. Bids received in excess of the ABC shall be automatically rejected at bid opening.
- The Civil Aviation Authority of the Philippines now invites bids for the above Procurement Project. Completion of the Works is required within One Hundred Fifty (150) Calendar Days upon receipt of the NOTICE TO PROCEED. Bidders should have completed a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II (Instructions to Bidders).
- 3. Bidding will be conducted through open competitive bidding procedures using nondiscretionary "*pass/fail*" criterion as specified in the 2016 revised Implementing Rules and Regulations (IRR) of Republic Act (RA) No. 9184.
- 4. Interested bidders may obtain further information from the Civil Aviation Authority of the Philippines and inspect the Bidding Documents at the address given below from Monday to Friday, 8:00 AM to 5:00 PM
- 5. A complete set of Bidding Documents may be acquired by interested bidders on **30 October 2024 until the deadline of submission of bid** from the given address and website/s below and upon payment of the applicable fee for the Bidding Documents, pursuant to the latest Guidelines issued by the GPPB, in the amount of Php 25,000.00 (exclusive of any and all taxes imposed by relevant government agencies). The Procuring Entity shall allow the bidder to present its proof of payment for the fees by presenting the official receipt in person.
- The Civil Aviation Authority of the Philippines will hold a Pre-Bid Conference<sup>1</sup> on 07 November 2024 @ 9:30 AM through videoconferencing/webcasting via Zoom/Google Meet, which shall be open to prospective bidders.
- Bids must be duly received by the BAC Secretariat through manual submission at the office address as indicated below, on or before 19 November 2024 @ 9:30 AM. Late bids shall not be accepted.
- 8. All bids must be accompanied by a bid security in any of the acceptable forms and in the amount stated in **ITB** Clause 16.

<sup>&</sup>lt;sup>1</sup> May be deleted in case the ABC is less than One Million Pesos (PhP1,000,000) where the Procuring Entity may not hold a pre-bid conference.

- 9. Bid opening shall be on **19 November 2024** @ **9:30 AM** at the given address below *and*/or through Zoom/Google Meet. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.
- 10. The Civil Aviation Authority of the Philippines reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract at any time prior to contract award in accordance with Sections 35.6 and 41 of the 2016 revised Implementing Rules and Regulations (IRR) of RA No. 9184, without thereby incurring any liability to the affected bidder or bidders,
- 11. Upon payment of the bid documents, bidders must provide their respective email addresses to the BAC Secretariat. All communications, including but not limited to Notices, Resolutions, and Replies, among others, will be sent to the email address provided by the bidders. The date when such email was sent shall be considered the date of receipt of the bidder/s for purposes of complying with the requirements under RA 9184
- 12. For further information, please refer to:

#### ENGR. LEANDRO R. VARQUEZ

3<sup>rd</sup> Floor Supply, Procurement Building Civil Aviation Authority of the Philippines BAC Head Secretariat MIA Road Pasay City Telefax No. (02) 8246- 4988 loc. 2236 Email: bac@caap.gov.ph www.caap.gov.ph

13. You may visit the following websites: For downloading of Bidding Documents: *www.caap.gov.ph* 

> CAPTAIN EDGARDO G. DIAZ Chairperson, Bids & Awards Committee-Alpha

Section II. Instructions to Bidders

#### 1. Scope of Bid

The Procuring Entity, Civil Aviation Authority of the Philippines invites Bids for the Purchase/Installation of Precision Approach Path Indicator (PAPI) System with Project Identification Number **BID NO. 24-095-10 ALPHA.** 

The Procurement Project (referred to herein as "Project") is for the construction of Works, as described in Section VI (Specifications).

#### 2. Funding Information

- 2.1. The GOP through the source of funding as indicated below for CY 2024 -2025 Multi-year budget (MYB) in the amount of **PHP 25,783,595.22**
- 2.2. The source of funding is:

GOCC and GFIs, the Corporate Operating Budget.

#### 3. Bidding Requirements

The Bidding for the Project shall be governed by all the provisions of RA No. 9184 and its 2016 revised IRR, including its Generic Procurement Manual and associated policies, rules and regulations as the primary source thereof, while the herein clauses shall serve as the secondary source thereof.

Any amendments made to the IRR and other GPPB issuances shall be applicable only to the ongoing posting, advertisement, or invitation to bid by the BAC through the issuance of a supplemental or bid bulletin.

The Bidder, by the act of submitting its Bid, shall be deemed to have inspected the site, determined the general characteristics of the contracted Works and the conditions for this Project, such as the location and the nature of the work; (b) climatic conditions; (c) transportation facilities; (c) nature and condition of the terrain, geological conditions at the site communication facilities, requirements, location and availability of construction aggregates and other materials, labor, water, electric power and access roads; and (d) other factors that may affect the cost, duration and execution or implementation of the contract, project, or work and examine all instructions, forms, terms, and project requirements in the Bidding Documents.

## 4. Corrupt, Fraudulent, Collusive, Coercive, and Obstructive Practices

The Procuring Entity, as well as the Bidders and Contractors, shall observe the highest standard of ethics during the procurement and execution of the contract. They or through an agent shall not engage in corrupt, fraudulent, collusive, coercive, and obstructive practices defined under Annex "I" of the 2016 revised IRR of RA No. 9184 or other integrity violations in competing for the Project.

#### 5. Eligible Bidders

5.1. Only Bids of Bidders found to be legally, technically, and financially capable will be evaluated.

5.2. The Bidder must have an experience of having completed a Single Largest Completed Contract (SLCC) that is similar to this Project, equivalent to at least fifty percent (50%) of the ABC adjusted, if necessary, by the Bidder to current prices using the PSA's CPI, except under conditions provided for in Section 23.4.2.4 of the 2016 revised IRR of RA No. 9184.

A contract is considered to be "similar" to the contract to be bid if it has the major categories of work stated in the **BDS**.

- 5.3. For Foreign-funded Procurement, the Procuring Entity and the foreign government/foreign or international financing institution may agree on another track record requirement, as specified in the Bidding Document prepared for this purpose.
- 5.4. The Bidders shall comply with the eligibility criteria under Section 23.4.2 of the 2016 IRR of RA No. 9184.

#### 6. Origin of Associated Goods

There is no restriction on the origin of Goods other than those prohibited by a decision of the UN Security Council taken under Chapter VII of the Charter of the UN.

#### 7. Subcontracts

7.1. The Bidder may subcontract portions of the Project to the extent allowed by the Procuring Entity as stated herein, but in no case more than fifty percent (50%) of the Project.

The Procuring Entity has prescribed that:

#### Subcontracting is not allowed.

#### 8. **Pre-Bid Conference**

The Procuring Entity will hold a pre-bid conference for this Project on the specified date and time and either at its physical address and/or through videoconferencing/webcasting} as indicated in paragraph 6 of the **IB**.

#### 9. Clarification and Amendment of Bidding Documents

Prospective bidders may request for clarification on and/or interpretation of any part of the Bidding Documents. Such requests must be in writing and received by the Procuring Entity, either at its given address or through electronic mail indicated in the **IB**, at least ten (10) calendar days before the deadline set for the submission and receipt of Bids.

#### **10.** Documents Comprising the Bid: Eligibility and Technical Components

- 10.1. The first envelope shall contain the eligibility and technical documents of the Bid as specified in **Section IX. Checklist of Technical and Financial Documents**.
- 10.2. If the eligibility requirements or statements, the bids, and all other documents for submission to the BAC are in foreign language other than English, it must be accompanied by a translation in English, which shall be authenticated by the appropriate Philippine foreign service establishment, post, or the equivalent office having jurisdiction over the foreign bidder's affairs in the Philippines. For Contracting Parties to the Apostille Convention, only the translated documents shall be authenticated through an apostille pursuant to GPPB Resolution No. 13-2019 dated 23 May 2019. The English translation shall govern, for purposes of interpretation of the bid.
- 10.3. A valid PCAB License is required, and in case of joint ventures, a valid special PCAB License, and registration for the type and cost of the contract for this Project. Any additional type of Contractor license or permit shall be indicated in the **BDS**.
- 10.4. A List of Contractor's key personnel (e.g., Project Manager, Project Engineers, Materials Engineers, and Foremen) assigned to the contract to be bid, with their complete qualification and experience data shall be provided. These key personnel must meet the required minimum years of experience set in the **BDS**.
- 10.5. A List of Contractor's major equipment units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership, certification of availability of equipment from the equipment lessor/vendor for the duration of the project, as the case may be, must meet the minimum requirements for the contract set in the **BDS**.

#### 11. Documents Comprising the Bid: Financial Component

- 11.1. The second bid envelope shall contain the financial documents for the Bid as specified in **Section IX. Checklist of Technical and Financial Documents**.
- 11.2. Any bid exceeding the ABC indicated in paragraph 1 of the **IB** shall not be accepted.
- 11.3. For Foreign-funded procurement, a ceiling may be applied to bid prices provided the conditions are met under Section 31.2 of the 2016 revised IRR of RA No. 9184.

#### 12. Alternative Bids

Bidders shall submit offers that comply with the requirements of the Bidding Documents, including the basic technical design as indicated in the drawings and specifications. Unless there is a value engineering clause in the **BDS**, alternative Bids shall not be accepted.

#### 13. Bid Prices

All bid prices for the given scope of work in the Project as awarded shall be considered as fixed prices, and therefore not subject to price escalation during contract implementation, except under extraordinary circumstances as determined by the NEDA and approved by the GPPB pursuant to the revised Guidelines for Contract Price Escalation guidelines.

#### 14. Bid and Payment Currencies

- 14.1. Bid prices may be quoted in the local currency or tradeable currency accepted by the BSP at the discretion of the Bidder. However, for purposes of bid evaluation, Bids denominated in foreign currencies shall be converted to Philippine currency based on the exchange rate as published in the BSP reference rate bulletin on the day of the bid opening.
- 14.2. Payment of the contract price shall be made in:

Philippine Pesos.

#### 15. Bid Security

- 15.1. The Bidder shall submit a Bid Securing Declaration or any form of Bid Security in the amount indicated in the **BDS**, which shall be not less than the percentage of the ABC in accordance with the schedule in the **BDS**.
- 15.2. The Bid and bid security shall be valid for the period specified in the **BDS** which <u>shall not exceed one hundred twenty (120) calendar days</u> from the date of the opening of bids. Any bid not accompanied by an acceptable bid security shall be rejected by the Procuring Entity as non-responsive.

#### 16. Sealing and Marking of Bids

Each Bidder shall submit one copy of the first and second components of its Bid.

The Procuring Entity may request additional hard copies and/or electronic copies of the Bid. However, failure of the Bidders to comply with the said request shall not be a ground for disqualification.

If the Procuring Entity allows the submission of bids through online submission to the given website or any other electronic means, the Bidder shall submit an electronic copy of its Bid, which must be digitally signed. An electronic copy that cannot be opened or is corrupted shall be considered non-responsive and, thus, automatically disqualified.

#### 17. Deadline for Submission of Bids

The Bidders shall submit on the specified date and time and either at its physical address or through online submission as indicated in paragraph 7 of the **IB**.

#### 18. Opening and Preliminary Examination of Bids

18.1. The BAC shall open the Bids in public at the time, on the date, and at the place specified in paragraph 9 of the **IB**. The Bidders' representatives who are present shall sign a register evidencing their attendance. In case videoconferencing, webcasting or other similar technologies will be used, attendance of participants shall likewise be recorded by the BAC Secretariat.

In case the Bids cannot be opened as scheduled due to justifiable reasons, the rescheduling requirements under Section 29 of the 2016 revised IRR of RA No. 9184 shall prevail.

18.2. The preliminary examination of Bids shall be governed by Section 30 of the 2016 revised IRR of RA No. 9184.

#### **19.** Detailed Evaluation and Comparison of Bids

- 19.1. The Procuring Entity's BAC shall immediately conduct a detailed evaluation of all Bids rated "*passed*" using non-discretionary pass/fail criteria. The BAC shall consider the conditions in the evaluation of Bids under Section 32.2 of 2016 revised IRR of RA No. 9184.
- 19.2. If the Project allows partial bids, all Bids and combinations of Bids as indicated in the **BDS** shall be received by the same deadline and opened and evaluated simultaneously so as to determine the Bid or combination of Bids offering the lowest calculated cost to the Procuring Entity. Bid Security as required by **ITB** Clause 16 shall be submitted for each contract (lot) separately.
- 19.3. In all cases, the NFCC computation pursuant to Section 23.4.2.6 of the 2016 revised IRR of RA No. 9184 must be sufficient for the total of the ABCs for all the lots participated in by the prospective Bidder.

#### 20. Post Qualification

Within a non-extendible period of five (5) calendar days from receipt by the Bidder of the notice from the BAC that it submitted the Lowest Calculated Bid, the Bidder shall submit its latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS), and other appropriate licenses and permits required by law and stated in the **BDS**.

#### 21. Signing of the Contract

The documents required in Section 37.2 of the 2016 revised IRR of RA No. 9184 shall form part of the Contract. Additional Contract documents are indicated in the **BDS**.

# Section III. Bid Data Sheet

# **Bid Data Sheet**

<b>ITB Clause</b>								
5.2	<ul> <li>For this purpose, contracts similar to the Project shall be:</li> <li>a. Purchase/Supply/Delivery/Installation of Airfield Lighting Systems (Precision Approach Path Indicator System).</li> <li>b. Completed within <b>10 years prior</b> to deadline for the submission and receipt of bids.</li> </ul>							
7.1	Subcontracting is not allowed							
10.3	A valid PCAB License is required, and in case of joint ventures, a valid special PCAB License, and registration for the type and cost of the contract for this Project.							
	Single Largest Project comple (ARCC) for registration of con shall be submitted together wi License Categorization	ng financial requirements eted (SLP); and Allowable tractors for government pr th the Bid. n – <b>Specialty, SP-NF</b> ( <b>Navig</b>	ational Facilities)					
	SLP / ARCC	- Medium A / Category B						
	Bids not complying wi	th the above instructions s	hall be disqualified					
10.4	The key personnel must meet	the required minimum yea	rs of experience set below:					
	Key Personnel -One (1) Project Manager/licensed electrical engineer -One (1) Project Engineer/licensed civil engineer -Three (3) Foreman	General ExperienceRelevant Experience-Minimum 10 years' experience- Managed Project in the installation of Airfield Lighting System-at least 5 years- Project engineer in the installation of Airfield Lighting System-at least 3 years-has working experience in the installation of AFLS						
	Bids not complying v	vith the above instructions	shall be disqualified					
10.5	The minimum major equipn	nent requirements are th	e following:					
		Equipment Sorvice truck						
	1 unit	Backhoe						
	1 unit	Dacknoe Hydraulic Crane						
	3 units	Genset with floodlight						
	1 unit	Concrete cutter						
	1unit	Water pump						
	1unit	Bar cutter						
	1 unit	Boring machine						
	1unit	Insulation tes	ter					
	1unit	Earth resistar	nce tester					
		Lux meter						
	1 UNIT	Compactor Power tools						

	Bids not complying with the above instructions shall be disqualified
15.1	<ul> <li>The bid security shall be in the form of a Bid Securing Declaration or any of the following forms and amounts:</li> <li>a. The amount of not less than 2% of ABC (= Php 515,672.00), if bid security is in cash, cashier's/manager's check, bank draft/guarantee or irrevocable letter of credit;</li> <li>b. The amount of not less than 5% of ABC (= Php 1,289,179.76) if bid security is in Surety Bond.</li> </ul>
16.0	<ol> <li>Each and every page thereof should be initialed/signed by the duly authorized representative/s of the Bidder. Submitted Eligibility, Technical and Financial documents should be properly marked with index tabs (ear tab) and to be sequentially paginated in accurate order in the form i.e. "page 3 of 100". Page number of last page of the document (per envelope basis). Pagination should be sequential based on the entire span of the whole documents inside the envelope.</li> <li>Each Bidder must submit <b>one (1)</b> original bid.</li> </ol>
19.2	<b>Partial bid is not allowed.</b> The infrastructure project is packaged in a single lot and the lot shall not be divided into sub-lots for the purpose of bidding, evaluation, and contract award.
20	<ul> <li>The Bidder with the Lowest Calculated Bid (LCB) that complies with and is responsive to all the requirements and conditions shall submit its</li> <li>a) Latest income and business tax returns filed through the Electronic Filing and Payment System (EFPS);</li> <li>b) Key personnel licenses</li> <li>c) Certificate of Site Inspection (refer to Annex -1) duly signed by Air Navigation Service (ANS) Facility-in-Charge or his/her duly authorized representative with the following documents as attachment; (a) Copy of company ID of the person who conducted the site inspection (b) Copy of the airport/facility visitor's logbook appearing the names and signatures of inspectors (c) Pictures of the proposed site including the personnel who conducted the site inspection together with the ANS Facility-in-Charge or his/her duly authorized representative.</li> <li>d) Certification, under oath, attesting that they have no pending case(s) against the Government, in addition to the eligibility requirements as prescribe under 2016 Revise Implementing Rules and Regulation (R-IRR) of RA 9184.</li> <li>e) Legal Clearance to be issued by the CAAP Enforcement and Legal Service with respect to the non-pending cases of the prospective bidders against this Authority</li> <li>f) Bid bulletin (if any)</li> </ul>

	documents submitted is made, it shall cause the forfeiture of the Bid Security in accordance with Section 69 of the IRR of RA 9184.
21	<ul> <li>The following relevant project documents are required to be submitted by the successful bidder who submitted the LCRB as part of the Contract Agreement during its signing: <ul> <li>a) Construction schedule</li> <li>b) Bar Chart &amp; S-curve</li> <li>c) PERT/CPM Network Diagram</li> <li>d) Manpower schedule</li> <li>e) Construction methods</li> <li>f) Equipment utilization schedule</li> <li>g) Shop/Construction Drawing</li> <li>h) Construction Safety &amp; Health Programs approved by the Department of Labor &amp; Employment for the Pur- chase/Installation of Precision Approach Path Indicator (PAPI) System at San Vicente Airport Palawan, Philippines.</li> </ul> </li> </ul>

# Section IV. General Conditions of Contract

# 1. Scope of Contract

This Contract shall include all such items, although not specifically mentioned, that can be reasonably inferred as being required for its completion as if such items were expressly mentioned herein. All the provisions of RA No. 9184 and its 2016 revised IRR, including the Generic Procurement Manual, and associated issuances, constitute the primary source for the terms and conditions of the Contract, and thus, applicable in contract implementation. Herein clauses shall serve as the secondary source for the terms and conditions of the Contract.

This is without prejudice to Sections 74.1 and 74.2 of the 2016 revised IRR of RA No. 9184 allowing the GPPB to amend the IRR, which shall be applied to all procurement activities, the advertisement, posting, or invitation of which were issued after the effectivity of the said amendment.

## 2. Sectional Completion of Works

If sectional completion is specified in the **Special Conditions of Contract (SCC)**, references in the Conditions of Contract to the Works, the Completion Date, and the Intended Completion Date shall apply to any Section of the Works (other than references to the Completion Date and Intended Completion Date for the whole of the Works).

## 3. Possession of Site

- 3.1 The Procuring Entity shall give possession of all or parts of the Site to the Contractor based on the schedule of delivery indicated in the **SCC**, which corresponds to the execution of the Works. If the Contractor suffers delay or incurs cost from failure on the part of the Procuring Entity to give possession in accordance with the terms of this clause, the Procuring Entity's Representative shall give the Contractor a Contract Time Extension and certify such sum as fair to cover the cost incurred, which sum shall be paid by Procuring Entity.
- 3.2 If possession of a portion is not given by the above date, the Procuring Entity will be deemed to have delayed the start of the relevant activities. The resulting adjustments in contract time to address such delay may be addressed through contract extension provided under Annex "E" of the 2016 revised IRR of RA No. 9184.

## 4. The Contractor's Obligations

The Contractor shall employ the key personnel named in the Schedule of Key Personnel indicating their designation, in accordance with **ITB** Clause 10.4 and specified in the **BDS**, to carry out the supervision of the Works.

The Procuring Entity will approve any proposed replacement of key personnel only if their relevant qualifications and abilities are equal to or better than those of the personnel listed in the Schedule.

## 5. Performance Security

5.1. Within ten (10) calendar days from receipt of the Notice of Award from the Procuring Entity but in no case later than the signing of the contract by both

parties, the successful Bidder shall furnish the performance security in any of the forms prescribed in Section 39 of the 2016 revised IRR.

5.2. The Contractor, by entering into the Contract with the Procuring Entity, acknowledges the right of the Procuring Entity to institute action pursuant to RA No. 3688 against any subcontractor be they an individual, firm, partnership, corporation, or association supplying the Contractor with labor, materials and/or equipment for the performance of this Contract.

#### 6. Site Investigation Reports

The Contractor, in preparing the Bid, shall rely on any Site Investigation Reports referred to in the **SCC** supplemented by any information obtained by the Contractor.

#### 7. Warranty

- 7.1. In case the Contractor fails to undertake the repair works under Section 62.2.2 of the 2016 revised IRR, the Procuring Entity shall forfeit its performance security, subject its property(ies) to attachment or garnishment proceedings, and perpetually disqualify it from participating in any public bidding. All payables of the GOP in his favor shall be offset to recover the costs.
- 7.2. The warranty against Structural Defects/Failures, except that occasioned-on force majeure, shall cover the period from the date of issuance of the Certificate of Final Acceptance by the Procuring Entity. Specific duration of the warranty is found in the **SCC**.

## 8. Liability of the Contractor

Subject to additional provisions, if any, set forth in the **SCC**, the Contractor's liability under this Contract shall be as provided by the laws of the Republic of the Philippines.

If the Contractor is a joint venture, all partners to the joint venture shall be jointly and severally liable to the Procuring Entity.

#### 9. Termination for Other Causes

Contract termination shall be initiated in case it is determined *prima facie* by the Procuring Entity that the Contractor has engaged, before, or during the implementation of the contract, in unlawful deeds and behaviors relative to contract acquisition and implementation, such as, but not limited to corrupt, fraudulent, collusive, coercive, and obstructive practices as stated in **ITB** Clause 4.

#### 10. Dayworks

Subject to the guidelines on Variation Order in Annex "E" of the 2016 revised IRR of RA No. 9184, and if applicable as indicated in the **SCC**, the Dayworks rates in the Contractor's Bid shall be used for small additional amounts of work only when the Procuring Entity's Representative has given written instructions in advance for additional work to be paid for in that way.

#### 11. Program of Work

- 11.1. The Contractor shall submit to the Procuring Entity's Representative for approval the said Program of Work showing the general methods, arrangements, order, and timing for all the activities in the Works. The submissions of the Program of Work are indicated in the **SCC**.
- 11.2. The Contractor shall submit to the Procuring Entity's Representative for approval an updated Program of Work at intervals no longer than the period stated in the **SCC**. If the Contractor does not submit an updated Program of Work within this period, the Procuring Entity's Representative may withhold the amount stated in the **SCC** from the next payment certificate and continue to withhold this amount until the next payment after the date on which the overdue Program of Work has been submitted.

## 12. Instructions, Inspections and Audits

The Contractor shall permit the GOP or the Procuring Entity to inspect the Contractor's accounts and records relating to the performance of the Contractor and to have them audited by auditors of the GOP or the Procuring Entity, as may be required.

## 13. Advance Payment

The Procuring Entity shall, upon a written request of the Contractor which shall be submitted as a Contract document, make an advance payment to the Contractor in an amount not exceeding fifteen percent (15%) of the total contract price, to be made in lump sum, or at the most two installments according to a schedule specified in the **SCC**, subject to the requirements in Annex "E" of the 2016 revised IRR of RA No. 9184.

## 14. **Progress Payments**

Such requests for payment shall be verified and certified by the Procuring Entity's Representative/Project Engineer. Except as otherwise stipulated in the **SCC**, materials and equipment delivered on the site but not completely put in place shall not be included for payment.

## 15. Operating and Maintenance Manuals

- 15.1. If required, the Contractor will provide "as built" Drawings and/or operating and maintenance manuals as specified in the **SCC.**
- 15.2. If the Contractor does not provide the Drawings and/or manuals by the dates stated above, or they do not receive the Procuring Entity's Representative's approval, the Procuring Entity's Representative may withhold the amount stated in the **SCC** from payments due to the Contractor.

# Section V. Special Conditions of Contract

# **Special Conditions of Contract**

GCC Clause	
2	Not applicable
3.1	The <b>CIVIL AVIATION AUTHORITY OF THE PHILIPPINES</b> shall give possession of all parts of the site to the Contractor upon receipt of the Notice to Proceed.
7.2	The Project has a total of two (2) year warranty period. The warranty covers a one (1) year full maintenance and service warranty upon the completion of the project [or known as defective liability warranty period (DLP)] at no extra cost to the contract followed by another one (1) year Service Warranty period
10	No dayworks are applicable to the contract.
11.1	The Contractor shall submit the Program of Work to the Procuring Entity's Representative <b>within</b> [7] days of delivery of the Notice of Award.
11.2	The amount to be withheld for late submission of an updated Program of Work is the <b>price amount of the contract</b> .
13	No advance payment or mobilization fees shall be given to the contractor for this Project.
14	No further instructions
15.1	The date by which operating and maintenance manuals are required is <b>upon the completion of the Project</b> .
	The date by which "as built" drawings are required is <b>upon completion of the Project.</b>
	PDF/CAD file on the "as built plan" shall be included as attachment to the required hard copy of the same upon completion of the Project.
15.2	The amount to be withheld for failing to produce the "as built" drawings and/or operating and maintenance manuals by the date required is two (2) percent (%) of the contract price.

# Section VI. Specifications

#### PART A

#### GENERAL REQUIREMENTS

#### 1.0 GENERAL

Purchase/Installation of Precision Approach Path Indicator (PAPI) System at San Vicente Airport (hereinafter referred to as the "Project") shall comprised of electrical/civil works of Aeronautical Ground Lightings of PAPI System.

#### 2.0 SCOPE OF WORKS

This Specification concerns the provision of the contractor's facilities, the design (where applicable), manufacture and testing at manufacturer's premises, delivery to site, carrying out all works, installation, testing at site, setting in operation, and handing over in perfect operating and running condition.

Works shown on the Drawings and not mentioned or described in the Specification and works described in the Specification and not shown on the Drawings will nevertheless be considered as included in this scope of Works and their execution will be deemed to be included in the Contract Price.

Any matter not provided in the Specification shall be determined through consultation between the Engineer and the Contractor.

The following principal features of the Work are included in the Proposal/ Contract, which shall be completed in a single package called for in the Proposal/Price Schedules Formats and subject to all conditions set forth in the Contract/Documents:

- (1) Mobilization/Delivery
- (2) Trenching/Excavation/Conduit and cabling works
- (3) Supply/Installation of PAPI Units
- (4) Supply/Installation of Constant Current Regulator
- (5) Supply/Installation of isolation transformers
- (6) Supply/installation of air conditioning units
- (7) Wiring and termination
- (8) Electrical testing and commissioning
- (9) PAPI's Flight Check/Commissioning
- (10) On-site maintenance training.

#### 3.0 CODES AND STANDARDS

Characteristics of the Aeronautical Ground Lighting (PAPI System) shall, except when clearly indicated otherwise in the Specifications, conform to the following ICAO Standards and Recommendations, Aerodrome Design Manual,

IEC International Standards and Other related national or international regulations and agreements.

- 1. Annex 14 Aerodromes (Latest Edition July 2018)
- 2. Aerodrome Design Manual, Part 4 Visual Aids (5th Edition 2021)
- 3. Airport Service Manual, Part 9 Airport Maintenance Practices (latest edition)
- 4. IEC International Standards (IEC-TC-97) for design, installation, verification, and maintenance of Aeronautical Ground Lighting of aerodromes

Unless specified otherwise in this Specification, design, materials, manufacture, and testing of all works shall comply with the following Standards and recommendations;

- ICAO Aerodrome Design Manual Part 5 Electrical Systems (2nd Edition - 2017)
- ICAO Airport Services Manual Part 8 Airport Operational Services
- IEC- International Electrotechnical Commission Publications
- ISO- International Organization for Standardization
- CIE- Commission Internationale de l'Eclairage (International Commission on Illumination)
- PEC- Philippine Electrical Code (Part 1 and Part 2)
- NSCP National Structural Code of Philippines
- MOS- Manual of Standards for Aerodromes by CAAP (2<sup>nd</sup> Edition 2017)

Materials, devices and small parts may comply with the national or international authorized Standard prevalent in the country of manufacture. However, adequate modification shall be made for the point of interface with the facilities provided in accordance with Standards and regulations of Philippine Electrical Code (PEC).

#### 4.0 DESIGN AND MANUFACTURE

All equipment and materials to be provided under this Specification shall be installed on the Site and shall be capable of working continuously under following conditions.

Ambient temperature	Inside room 10°C- 45°C				
	Outside 10°C – 55°C				
Relative humidity	Inside room Max 95%				

Outside Max. 100%					
Max. wind speed	60m/second				
Rainfall	Around 2200mm/ year (Ave. 158 rain day) 389 mm/month (highest), up to 210mm/hr				

- (1) The Contractor shall submit the design documents to the CAAP for approval within twenty (20) days from the Commencement Date. The CAAP shall be advised if any change in design if found necessary after original approval is granted. The CAAP may require re-approval if they involve changes in concept, approach, quantity, size or weight, power requirements, performance.
- (2) The design documents shall include drawings of proposed structures, CCR capacity calculations, lamp wattage, number of lamps, intensity distribution diagrams and average intensity, cable size and voltage drop calculations.
- (3) Cubicles for electrical power distribution equipment shall be provided with proper ventilation grilles, and these ventilation grilles shall be designed to ensure rodents will not enter the cubicles.
- (4) Not less than 30 days prior to the shipment of the related equipment or structures, two final draft copies of installation instructions, drawings and maintenance and operation manuals shall be submitted to the Engineer for approval.
- (5) Within twenty (20) days from the commencement date, the contractor is required to submit a copy of Certificate of Frangibility or proof of frangibility from its suppliers/manufacturers to the CAAP. The certificate guarantees that all equipment and/or structures to need to be installed within the safety area, obstacle free zone, and runway strip shall withstand under normal environmental conditions but break away or collapse when impacted by an aircraft.

#### 5.0 SPARE PARTS

- (1) General
  - a. The Contractor shall assure the availability of spare parts of the same type or substitutes of equal or better quality for at least ten (10) years after the issue of the Acceptance Certificate. The Bidder shall submit Certificate of after sales support for at least 10 years with the bid.
  - **b.** All such cases, containers, cable drums or other packages are liable to be opened for such examination as the Engineer may reasonably require, and all such opening and subsequent repacking shall be at the expense of the Contractor.

#### 6.0 TOOLS/APPLIANCES AND MEASURING INSTRUMENT

#### (1) General

- a. Tools / Appliances and Measuring Instrument for normal maintenance shall be supplied by the Contractor as indicated in the Bill of Materials / Quantities.
- b. Each tool and appliances shall be clearly marked with its size and/or purpose where necessary.
- c. The tools and appliances with appropriate boxes shall be handed over to the Engineer prior to the issuance of the Taking-over Certificate.
- d. The tools and appliances supplied shall not be used for erection purposes.
- e. The scope of tools and devices for assembly and maintenance shall include all customary tools and devices and tools which are specially made and/or required for complete assembling, dismantling, adjustment and maintenance of all equipment.
- (2) Electrical Power Equipment
  - a. The electrical panels shall be of self-contained cubicle type, floor standing, with a full front face door, and/or rear access, with cable entry from the bottom.
  - b. Each electrical and power equipment shall be separated from another unit by a completely grounded steel plate, and high tension and low-tension circuits shall also be separated by a completely grounded steel plate. The housing for the various components shall be constructed of fabricated steel.
  - c. Adequate ventilation shall be provided to enable the equipment to operate continuously under the local ambient temperature designated hereinabove, and the same time care should be taken into account of rodents.
  - d. Precautions shall be taken to prevent overheating through hysteresis and eddy current loss.
  - e. All electrical equipment shall be provided with a suitable grounding terminal.
  - f. All electrical instruments and meters to be mounted on electrical panels shall be accurate to within  $\pm 1.5\%$ , flush-mounting type with dustproof cover measuring 80mm 110mm square.

Wherever necessary, instruments shall be provided with easily accessible zero adjuster.

- g. All control panel wiring and secondary control wiring in circuit breakers, control gear and the like shall be made in a neat and systematic manner, with cables supported clear of the panels and other surfaces at all points to obtain free circulation of air.
  - 1. Wiring shall be color-coded in accordance with the latest edition of Philippine Electrical Code:
    - Green : Equipment Grounding (Non-carrying current conductor)
    - White/Gray : Neutral or Earth Ground

Red/Yellow/Black: All wiring other than grounding circuit

- 2. All wiring ends shall be marked to discriminate the circuits, voltage, current, fault circuit, etc.
- 3. The molded case circuit breakers (MCCB) shall be manually operated, trip free mechanism with electromagnetic or thermal-magnetic type tripping element.
- 4. Equipment shall be provided with lamps that indicate the stage of operation and a lamp test circuit shall be provided on the panel accordingly. Light emitting diode (LED) shall be adopted rather than filament lamp.
- (3) Grounding System
  - a. Generally
    - 1. The light fittings, secondary cables and secondary wires of isolating transformers, electro ducts, and exterior lighting poles shall be grounded for lightning protection.
    - 2. The grounding system shall be provided properly for safeguard to the person, equipment, light unit, and fitting, etc.
    - 3. The grounding of equipment, lights, poles, and masts shall be made mechanically and electrically to ensure the continuous system, and shall be conductive.
    - 4. The common grounding counterpoise wires of the grounding system and lightning system shall be used for light fitting and light units.

- 5. Connections between grounding rods and the grounding cables shall be welded exothermically. (i.e. Cad weld or its equivalent)
- 6. Counterpoise wires

The lightning protection wires shall be installed above underground cables and power cables for linked circuits.

- 7. Grounding Wires
  - (a) The grounding wires to be used in this work shall be manufactured and tested in accordance with the appropriate standards authorized in the country of manufacture or equivalent thereto.
- 8. Equipment
  - (a) Common grounding wire shall be installed in the cable pit. The wire shall be connected to copper grounding plates, or rods and shall also be connected with the grounding terminal of equipment.
  - (b) The copper grounding plates and rods shall be installed underground to a depth of not less than 1.0m. Grounding resistance of the system as a whole shall not exceed 5 ohms.

#### 7.0 CIVIL WORKS (Site Works)

- (1) General
  - a. This work shall be applied for the installation of mounting light bases, hand-holes, maintenance holes, foundations, concrete base for cubicle/panel and outdoor cable trench.
  - b. Foundations for equipment shall be sufficient size and thickness as recommended by the equipment manufacturer.
  - c. Design of conduit encasement system shall consider factors such as load-bearing capacity required to support the weight of aircraft and other surface traffic.
  - d. Conduit encasement systems must comply with relevant engineering and aviation standards to ensure safety and structural integrity.
  - e. No pouring of concrete shall be done by the contractor unless bearing surfaces has been inspected and approved by Engineer, and the authority to proceed has been received by the contractor.

- f. The contractor shall protect and maintain all conduits, drains, sewer pipes and other utility that are on the property.
- (2) Excavation and Backfill Work
  - a. The depth and width of excavation shall be of minimum for the installation of above facilities. The bottom plane of excavation shall be flat.
  - Excavated material may be used for backfill provided it is free of stones and other objects that can cause cable damage. Backfilling shall be put in horizontal layers **not to exceed every** 250mm in depth, and shall be compacted to the satisfaction of the Engineer.
  - c. The backfill of the trenches shall be in accordance with the specifications of ICAO Aerodrome Design Manual Part 5-Electrical Systems.
  - d. The cables in the trenches shall be carefully laid over **100mm** of sand cushion, on top of the cables another 100mm of sand layer shall be added before backfilling. To secure proper spacing horizontally and vertically adequate jigs shall be used during cable laying.
  - e. The installation of concrete encasement involves excavating the ground beneath the taxiway to create a trench for the conduit encasement.
  - f. The work shall include all materials, labor, equipment for leveling and clearing construction site and all other operations to complete the excavation/embankment/backfilling/gravel bedding of covered area as indicated in the plans.
  - g. Restore the construction site to its original condition, including resurfacing and landscaping as necessary.

#### 8.0 OTHER WORKS

#### **CCR Area Modification**

#### (1) **Project Overview:**

The project involves minor modifications of the equipment room to accommodate the installation of two 2.5 HP air conditioning units, providing window heat insulation, and installation of two stainless doors.

#### (2) **Preparation**

- a. The equipment room shall be cleared of all items and debris.
- b. Proper ventilation shall be ensured during renovation works.

#### (3) Air Conditioning Units Installation

- a. The air conditioning units shall be installed in accordance to the specified size and cooling requirements.
- b. The air conditioning units shall be placed according to the equipment layout for efficient air circulation and cooling.
- c. Units shall be connected to the electrical supply as specified in the equipment layout and shall be tested to work properly.
- d. The air conditioning unit's compressor must be installed outside the building placed with a minimum wall clearance of 8 to 12 inches, and place on a concrete base to support the weight of the compressor at least 6 inches above the ground <u>or</u> use a strong rust-proof brackets to elevate the compressor above the specified ground clearance.
- e. Install the refrigerant lines properly, ensuring no kinks, sharp bends or leaks.
- f. Connect the compressor to the electrical supply according to the Philippine Electrical Code by using the correct size of wiring and breakers.
- g. Perform a test run for unusual vibrations, noise, or leaks after installation.
- h. Ensure proper sealing around edges to prevent water ingress.

#### (4) Fire-Rated Stainless Door Installation:

- a. Remove any existing door and frame.
- b. A stainless door shall be installed matching the existing specifications.
- c. Ensure proper fitting, alignment, and functionality of the new door.
- d. Install necessary hardware such as handles, locks, and hinges.

#### (5) Final Inspection and Cleanup:

- a. A thorough inspection of all renovated areas shall be conducted to ensure quality and compliance with specifications.
- b. Any defects or issues identified during inspection shall be rectified.
- **c.** All construction debris shall be removed and ensure the equipment room shall be left clean and tidy.

**Note:** All works should be carried out in accordance with relevant building codes, safety regulations, and manufacturer's instructions. Any deviations from the scope must be approved by the Authority.

#### 9.0 TESTS AND INSPECTION

- (1) Scope of Testing
  - a. The Contractor shall perform all the test activities specified in this Section.
  - b. The Contractor shall prepare and submit, at least thirty (30) days prior to any test carried out by the Contractor, two sets of detailed test procedures and schedules to the CAAP for consideration and approval. Test procedures shall be comprehensive and shall demonstrate equipment hardware compliance with all the requirements of this Specification.
  - c. The entire work to be executed by the Contractor is subject to inspection and tests by the CAAP during installation and on completion at the Site, but the approval of the CAAP or the passing of any such inspection or test shall not, however, prejudice the right to reject the items or equipment if they do not comply with the Specification when installed.
  - d. Tests shall include the following:
    - 1. Tests at factory by the Contractor/Manufacturer
    - 2. Tests at the Site during construction
    - 3. Commissioning Tests
    - 4. Reliability Tests
    - 5. Other tests
  - e. The Contractor should carry out and submit the test documents according to the following Table 1

Test Item	1	2	3	Standard	
Detail					
Composition Test	0			Approved Shop	
(Quality)				Drawings	
Appearance &	0		0	-do-	
Structure Test					
Dimensional Test	0			-do-	
Photometric Test	0			-do-	
Waterproof Test	0			FAA/ICAO spec.	
Alignment Test		0	0	Document for Test and	
-				Inspection	
Operation Test		0	0	-do-	
Notes:					

TABLE – 1. Test Items for Airfield Light Fittings

- 1. Test at factory by the Contractor/Manufacturer.
- Test at the Site during construction. 2.
- 3. Commissioning test.

TABLE - 2. Test Items for Constant Current Regulator

Test Item			2	3	Standard	
Detail						
Composition Test (Quality)		0		0	Approved Shop Drawings	
Appearance	& Structure Test	0			-do-	
Dimensional	Test	0			-do-	
Photometric	Test	0			-do-	
	1) Transitional Response Test	0			-do-	
Operation	2)Soft-starting Test	0			-do-	
Test	3) Brilliancy Tap Changing-over Test	0	0	0	-do-	
	4) Protective Device Test	0	0	0	-do-	
5)Overall Operational Test		0	0	0	-do-	
Insulation Resistance Test		0	0	0	FAA / ICAO Spec.	
Dielectric Test		0			-do-	

#### Notes:

- Test at factory by the Contractor himself.
   Test at the Site during construction.
- 3. Commissioning test.

Test Item	1	2	3	Standard
Detail				
Composition Test (Quality)	0			Approved Shop
				Drawings
Appearance & Structure Test	0		0	-do-
Dimensional Test	0			-do-
Insulation Resistance Test	0		0	-do-

TABLE - 3. for	Operation Test	0	0	0	FAA/ICAO specs.	Test Items Control		
	Dielectric Test	0			-do-			
Equipment								

#### Notes:

- 1. Test at factory by the Contractor himself.
- 2. Test at the Site during construction.
- 3. Commissioning test.
- (2) Test at Site during Construction
  - a. During the course of installation, the Engineer shall have full right for making tests and inspection for the work, as he may deem necessary always with the participation of the Employer's personnel in all tests at Site if so requested by CAAP for the purpose of onthe-job training. In this case, the Contractor may have part of the tests conducted by such personnel but shall assume final responsibilities for test results.
- (3) Other test

#### **During Trenching**

- a. To ensure the restoration of the surface of the taxiway, a visual inspection must be conducted to identify any visible damage or issues during the trenching process. The inspectors (i.e., engineer, contractor) shall visually examine the taxiway surface and adjacent areas as trenching progresses.
- b. Compaction Testing must be conducted to ensure proper compaction of backfill material during the trenching process by performing field compaction test to verify that the backfill material meets specified compaction standards.

#### After Trenching and conduit encasement installation

- a. Inspectors shall visually examine the restored surface for possible defects or irregularities such as unevenness or settling.
- b. Conduct field density test on the restored surface to ensure proper compaction.
- c. Conduct thickness measurement to assess the thickness of the pavement layers.
- d. Perform compressive strength testing to determine its compressive strength.
- e. Perform joint sealing inspection and if necessary, additional testing to assess the condition and performance of joint sealants.
- (4) Documents for Tests and Inspection

- a. Before execution of test and inspection, the Contractor shall prepare and submit the following documents to the Engineer for his approval:
  - 1. Complete description in writing about procedure of tests at Site.
  - 2. Complete description in writing about procedure of commissioning tests at the Site.
- b. Certified reading and data of all tests to be carried out by the Contractor shall be submitted to the Engineer from time upon completion of each test and the Contractor shall prepare additional four (4) copies of complete set of these test data bound in book form for submission at the time of the commissioning test.

#### **10.0 OPERATION AND MAINTENANCE MANUALS**

(1) Three (3) sets of Complete Operation and Maintenance Manuals in English shall be submitted to the CAAP not later than five (5) days before any site testing and commissioning.

#### 11.0 CABLE WORKS

(1) General

- a. Airfield lighting power and control cables shall be installed in ducts, or trench. Counterpoise wire and underground cable marker sheet shall be installed on top of the trench of cable ducts and underground cable.
  - b. The cable conductor size in the Specification and on the Drawings is given in mm or in mm<sup>2</sup>.
  - c. The following information shall be marked repeatedly on suitable part of the cable.

Manufacturer's Name and/or Trademark Size of Stranded Conductor Cross Section (for 5KV) Voltage Rating

- d. Cable length per cable drum shall be less than 2,000 meters, and a total weight of cable and drum shall be less than 5 tons, for easy transportation. The Contractor shall submit AFL power cable length list to the CAAP for approval before manufacturing.
- e. Where cable end projects from a drum they shall be adequately protected to prevent damage during handling and transportation,

and a thick PVC wrapper (cap) shall be placed over the cable to prevent the ingress of dirt, dust and grit, etc.

- f. Each drum shall bear a distinguishing number which is branded with hot iron or neatly chiseled on the outside of one flange. **Painted markings shall not be accepted**.
- g. Particulars of the cable, i.e. type of cable, rated voltage, length, conductor size, number of cores, gross and net weights, as well as position of cable end, manufacturer's name and year and a month of manufacturer shall be clearly shown on the drum. The direction of rolling shall be indicated by an arrow.
- (2) Underground Series Circuit Cable (5KV, 8mm<sup>2</sup>-single core)
  - a. Airfield lighting power cable shall be manufactured in accordance with ICAO Specifications.
  - b. Installed primary airfield lighting cables shall have cable circuit identification markers attached on both sides of each connector and on each airport lighting cable entering or leaving cable access points, such as manholes, handholes, pullboxes, junction boxes, etc. Tags size and thickness should be in accordance with Aerodrome Design Manual Part 5 Electrical System latest edition.
  - c. High voltage series circuit cables to be used in the Works shall be 8mm<sup>2</sup> single conductor, ethylene-polypropylene rubber insulated (EPR), polyvinyl-chloride or polychloroprene sheathed cables as follows:

Voltage Rating	kV	5	
No. of Conductor		-	1
Conductor	Nominal area	mm <sup>2</sup>	8
	No. and dia. of wires	No./mm	7/1.2
	Outside dia.	mm	3.6
EP Rubber Insulation	mm	4.0	
Polychloroprene She	mm	1.8	
Outside Dia. of Shea	mm	13.5	
AC Test Voltage (for	kV	17	
Insulation Resistance	meg ohm	900	
Conductor Resistanc	e per 1000 m (20) max	Ohm	2.41

TABLE - 4.Cable Details (1)

- d. The cable conductor will be tin or lead-alloy coated annealed stranded copper wires.
- e. The average thickness of the insulation and sheath shall not be less than 90% of the value given in Table 5. The minimum

thickness of the insulation and sheath at any point shall be not less than 80% of the specified value.

- (3) Extension Cables-Secondary (600V, 2 PNCT Cable) and Wires to the Light Fitting
  - a. The extension cable between the isolating transformer and light fitting shall be 4.0 mm<sup>2</sup> double-conductors, ethylene-polypropylene rubber insulated, polychloroprene sheathed portable cable. 2 PNCT Cable shall be manufactured in accordance with JIS-C 3327.
  - b. The secondary cables shall be provided either with a factory molded receptacle or factory molded plug, depending upon their location.

Voltage Rating	V	600	
No. of Cores	No. of Cores		
Conductor	Nominal cross-sectional area	mm <sup>2</sup>	8
	Composition and No. of wires	mm	45/0.32
	Outside dia.	mm	2.5
Thickness of Separat	or	mm	0.05
Thickness of Insulation	n	mm	0.8
Cabling Diameter app	proximately	mm	8.4
Thickness of Sheath		mm	1.9
Overall Dia. Of Cable	mm	12.5	
Weight of Cable per 1	1000 m, approx.	Kg	245
Conductor Resistance	e per 1000 m (20 °C) maximum	Ohm	5.54
AC Withstand Voltage	kV	3.0	
Insulation Resistance	Insulation Resistance for 1000 m (20°C) min		
		ohm	

#### TABLE - 5.Cable Details (2)

- (4) Plugs and Receptacles
  - a. Plugs and receptacles for the 5kV and 3kV single-conductor cables shall be designated for 25A current, and for the 600V, two-conductor cables for 20A.
  - b. The plug and receptacle shall be water tight and will withstand continuous use under the designed ambient temperature range. The connector plug and receptacle shall resist a pulling force equal to a static weight of 5 kg without becoming disconnected. All plugs and receptacles shall be identical and of uniform manufacture.
  - c. Plug and receptacles shall be manufactured in accordance with ICAO Standard.

d. The receptacle and the plug shall be factory molded on the cable end.

#### **12.0 ISOLATING TRANSFORMERS**

- (1) The types and characteristics of the isolating transformer to be supplied shall be as shown in Table 6.
- (2) All isolating transformers shall be suitable for use on series circuits with a current of 6.6 amperes.
- (3) All isolating transformers shall be completely waterproof, shall withstand continuous use under the designated ambient temperatures and shall be suitable for burying in the ground or setting in transformer boxes, as required. Each transformer shall be completely sealed together with the lead cable joints, in black vulcanized rubber with polychloroprene sheathing of 7 mm or more in thickness to ensure water tightness.
- (4) Two primary lead cables and one secondary lead cable shall be attached to the isolating transformer.
- (5) The primary lead cables shall be 340mm +/- 30mm in length, single cored, 8 mm<sup>2</sup> PN cables, the one with a receptacle and the other with a plug. The receptacle and the plug shall be factory molded.
- (6) The secondary lead cable shall be of 600V 2 x 3.5 mm<sup>2</sup> 2 PNCT, 1100 mm +/- 50 mm in length in principle, and provided with a factory-molded receptacle. Isolating transformers shall show rating information. The Contractor shall examine necessary length of the secondary lead cable in consideration of the overall height of light.
- (7) Isolating transformer shall be manufactured in accordance with ICAO Standard.

Characteristics	30/45 watts	150 watts	200 watts	Remarks
Primary Current (A)	6.6	6.6	6.6	100% load
Secondary Current (A)	6.53-67	6.53-67	6.53-67	
Secondary Current (A)	6.6-7.1	6.6-7.1	6.6-7.1	Short Circuit
Primary Power Factor (%)	Min. 95	Min. 95	Min. 95	100% load
Efficiency (%)	Min.85	Min.85	Min.90	100% load
Primary Voltage Regulation	Max.90	Max.80	Max.80	Open Circuit
(%)				
Frequency	60 Hz	60 Hz	60 Hz	

TABLE - 6. Isolating Transformer

#### **13.0 POWER AND CONTROL CABLES**

- (1) All power cables of parallel circuit, as well as all control cables to be used in the Works shall be manufactured in accordance with the following standards:
  - IEC International Electrotechnical Commission
  - JIS Japan Industrial Standard
  - JCS Japanese Cable Makers Association Standards
  - ICEA Insulated Cable Engineers Association, U.S.A
  - PEC Philippine Electrical Code
- (2) All power cables, except where otherwise specified, shall be crosslinked polyethylene (XLPE) insulated and polyvinyl-chloride sheathed cables.
- (3) All control cables, except where otherwise specified, shall be polyvinylchloride insulated, polyvinyl-chloride sheathed control cables.
- (4) Bare Copper Wire (Counterpoise Wires)
  - a. Bare copper wires for counterpoise installations shall be stranded or PVC insulated wire with a minimum size of 14 mm<sup>2</sup>. Preference will be given to 600 V polyvinyl-chloride insulated wires for long service life.
  - b. The grounding wires to be used in this work shall be manufactured and tested in accordance with the appropriate Standards authorized in the country of manufacture or equivalent.
- (5) Series Circuit Cable Joint
  - a. All joints of the series circuit cables including their extensions, as well as joints with lead cables of the isolating transformer shall be made by means of the plug and the receptacle factory-molded on cable ends.
  - b. Prior to joining, the plug and the receptacle shall be thoroughly cleaned to be free from greases, dust, etc.
  - c. Unless otherwise specified, all plug joints shall be protected by 4 layers of self-bonding tape, topped by 3 layers of PVC tape, with the exception of all connections with the secondary lead cable of the isolating transformer, whose receptacle shall be joined to the plug of the light fittings by means of a clamp.
- (6) Power and Control Cable Joint

- a. Joints and terminations of the power cable and control cables shall be executed in a manner to be approved by the CAAP. For the sake of easy access for maintenance, in principle all joints shall be made in the manholes or hand-holes.
- b. The Contractor shall submit joining point location plan for the CAAP approval within twenty (20) days from the Commencement Date.
- c. Full details of jointing materials shall be submitted to the CAAP for written approval, before shipment.
- (7) Installation
  - a. The approximate routes of the cables are shown on the Drawings. Actual laying positions of the cable ducts and of cable supports shall be determined with due regard to any obstacles that might exist as well as to accessibility of all such routes, subject to the approval of the CAAP prior to the installation.
  - b. PVC pipe ducts with concrete encasement and steel reinforced shall be used where cables are installed under the pavement area. Where crossing runways, taxiways, roads or aprons those underground cables shall be protected with ducts.
  - c. The series circuit cables, power cables, control cables and cables of radio navigational aids and communications shall be allocated separate duct pipes.
  - d. When the supply and return circuits of a series circuit are routed together, the cables for both directions shall be laid in the same duct pipe. However, when one lighting system receives its power supply through 2 circuits, the cables for each circuit shall be laid in separate pipes.
  - e. All cables shall be buried at least 600 mm below finished graded except for transformer secondary cable.
  - f. Minimum spacing between underground cables to be maintained:

Between same voltages				
Between 6 kV cables and 600 V cables	150mm			
Between 6 kV cables and light-current cables	300mm			
Between 5 kV cables and 600 V cables	150mm			
Between 5 kV cables and light-current cables	300mm			
Between 6 kV cables and light-current cables	300mm			

g. Each underground cable shall bear cable identification circuit markers for non-corrodible materials, as directed by the CAAP.

Cable installation shall be in accordance with the specification of L-824 cable.

- (8) Grounding System
  - a. A stranded bare copper wire 14 mm<sup>2</sup> minimum size shall be installed for lightning protection of the underground cables in trenches.
  - b. The copper wire shall be installed in the same trench for the entire length of the insulated cables; it shall be placed at a depth of approximately 300 mm or as indicated in the drawing above the insulated cables.
  - c. The grounding rods shall be installed not more than 300 m apart around the entire cable length. The grounding rods shall be made of copper clad steel, coupled type, 3 meters in length and 19 mm in diameter. The grounding resistance as a whole shall be less than 5 ohms. The grounding resistance of each electrode shall be not more than 20 ohms.
  - d. The grounding rod shall be installed not more than 750 mm in depth at the upper portion of the rod.

#### 14.0 MAINTENANCE AND REPAIR SERVICES

- (1) Service To Be Provided
  - a. The contractor shall be responsible for providing one year full maintenance and repair services for all the works for the duration of the Defects Liability Period (DLP) and for a further 12 months period after the issue of the Defect Liability Certificate (the total period to be hereinafter known as the Maintenance and Repair Period).
- (2) The Maintenance and repair services shall include:
  - a. Regular routine maintenance and inspection procedures at intervals detailed in the relevant Operation and Maintenance Manuals.
  - b. The provision of all consumables, lubricants, spares parts and replacement parts.
  - c. Repair services including an emergency repair capability within 12 hours of a call out from the CAAP (personnel will be designated in the future for this purpose)

- d. The Contractor shall remain responsible for the effective and efficient performance of the maintenance and repair services throughout the Maintenance and Repair Period and costs thereof shall be understood to be included in the respective rates of the Bill of Quantities.
- e. The maintenance and repair services are to be carried out by the Contractor or by an officially established and locally presented organization under the Contractor's responsibility, certified as being capable and authorized to provide such Services by the Contractor and the manufacturer of particular items of Plant, system or part of the Works concerned. Maintenance or repair work carried out by such an organization shall not be invalidate or in any way affect any the Contractor's express or implied guarantees or warranties for the Works.
- f. The maintenance and repair services should, as far as is practical, be carried out in the presence of the CAAP personnel to serve as ongoing operational and maintenance training.

# PART B

## PRECISION APPROACH PATH INDICATOR (PAPI) SYSTEM

#### **1.0** PRECISION APPROACH PATH INDICATOR (PAPI) SYSTEM

(1) Scope of Work

This work includes the supply and installation of brand new PAPI system including primary airfield lighting cables, grounding cables, constant current regulator, remote control box, excavation, sand bedding, backfilling & ancillaries to complete the work.

- (2) Lighting System
  - (a) Precision Approach Path Indicator (PAPI) System for Runway 04 and Runway 22 shall comprise a total of four (4) light units for each runway placed at left side of the runway and at right angles to the runway center line.
  - (b) Each light beam angle of elevation setting for 3-degree PAPI approach slope shall be 2°30', 2°50', 3°10, 3°30' respectively for both runway 04 and runway 22.
- (3) Light Units
  - (a) Each unit shall contain three (3) high intensity tungsten halogen lamps 6.6A 200W, 1,000 hours average rated life and shall comprise of aluminum plate housing containing the optical projectors, filters, lamps, lead cables, etc. with an adjustable positioning frame and four (4) mounting legs with adjustable sleeve and frangible coupling to give an adjustment in lateral, transversal, horizontal and elevation angle.
  - (b) The color transition from red to white in the vertical plane shall be such as to appear to an observer at a distance to occur up to vertical angle of not more than 3 minutes.
  - (c) The light distribution of each unit shall be in accordance with the specification of Appendix 2, Figure A2-23 of ICAO Annex 14 Volume 1 7<sup>th</sup> Edition, 2016.
  - (d) The intensity of the completely red beam immediately below the transition sector shall not be less than 15% of the intensity of the completely white beam immediately above the transition sector.
  - (e) The light unit housing shall be guaranteed against distortion due to sun or other climatic conditions prevailing on the site.
  - (f) Each light unit and supporting pipe shall be of lightweight, **frangible construction** suitable for concrete mounting base and shall be sufficient strength to withstand aircraft engine blast.
  - (g) Exterior finished color of light units shall be yellow.

- (4) Installation
  - (a) Each light unit shall be installed on top of concrete mounting base using a breakable coupling on aluminum frangible pipe.
  - (b) Four (4) light units shall be in the level when checked by precision level meter and electronic survey equipment.
  - (c) Exact position of light units to be installed shall be subject to the approval of the Engineer. Prior to erecting the concrete base, the Contractor shall place temporary markings to identify the actual installation positions of the light units determined by him through detailed site survey, against the corresponding positions indicated on the Drawings, and shall notify the Engineer accordingly.
  - (d) In azimuth the axis of the beams of all light units shall be parallel with the center line of the runway.
- (5) Isolating Transformer

A rubber-molded isolating transformer for the Precision Approach Path Indicator shall be installed in the transformer box.

(6) Power Supply System

The Precision Approach Path Indicator System to be installed at Runway 04 and Runway 22 shall be supplied with power from the power house respectively, by means of constant current high voltage series loop circuit of 6.6 amperes at 100% brilliance. Both PAPI systems shall be fed through the 5 KVA CCR, 220V-240V, 60 Hz, Single Phase with Circuit Selector for alternate operation.

The CCR and Circuit Selector shall be located at the powerhouse and primary series cables shall be installed from the powerhouse to the new PAPI units.

(7) Brilliancy Control

The Precision Approach Path Indicator System shall be controlled in five (5) brilliancy steps of 100%, 25%, 5%, 1% and 0.2% of the full brilliance, by means of Remote-Control Panel installed at ATC Tower Cab room.

# Section VII. Drawings

# Section VIII. Bill of Quantities

# BILL OF MATERIALS / COST ESTIMATE

<u>OTY</u>	<u>UNIT</u>		DESCRIPTION	<u>UNIT COST</u>	<u>AMOUNT</u>
		I.	GENERAL REQUIREMENTS		
1	lot		Mobilization & Demobilization		

Sub-Total

		II. SITE WORKS	
		II.1 Excavation Works	
940	m³	* PAPI Cable Run Trench (0.6m x 0.6m x L)	
131	m³	* PAPI Pavement (11m x 34m x 0.35m)	
131	m³	* PAPI Pavement (11m x 34m x 0.35m)	
117	m³	* Manholes (1.8m x 1.8m x 2m) x 18	
627	m³	II.2 Back Filling Works * PAPI Cable Run (0.6m x 0.4m x L)	

Labor

		111.	CIVIL WORKS
33	m	III.1	PVC Duct 110mm dia. in concrete
			encasement with re-bars including excavation, backfilling, compaction and pavement restoration. (Taxiway 1) <i>Refer to drawing for</i> <i>details</i>
33	m	III.2	PVC Duct 110mm dia. in concrete
			encasement with re-bars including excavation, backfilling, compaction and pavement restoration. (Taxiway 2). <i>Refer to drawing for</i> <i>details</i>
18	sets	III.3	Manhole equipped with/or equivalent and
			other accessories.
			* 650mmØ Cast Iron Cover * Hot Dip Galvanize Ladder Rung * 20mmØ x 3m Cu. Ground Rod * End Bells and Water Sealant * Lean Concrete and Gravel Bedding * Brass Floor Drain* 16mmØ and 12mmØ RSB @ 150mm spacing * Concrete (210 kg/cm <sup>2</sup> )
2	sets	111.4	Handhole equipped with/or equivalent and
	other accessories	other accessories	
			* 400mmx400mm Steel Frame Cover

Signature of Bidder's Authorized Representative

			* End Bells and Water Sealant	
			* Lean Concrete and Gravel Bedding	
			* Brass Floor Drain	
			* 12mmØ RSB @ 150mm spacing	
			* Concrete (210 kg/cm <sup>2</sup> )	
			* Galvanize Cable Support	
313	cu.m.	III.5	Fine Sand for Trench Bedding (0.2m x	
			0.6m x L)	
2	lot	III.6	Concrete Pavement	
			* 10m x 33m x 0.1m Concrete (150kg/cm <sup>2</sup> ) or better	
			<ul> <li>* 10mmØ RSB @ 300mm spacing</li> <li>* 100mm Thick Crushed Aggregates Bedding</li> </ul>	

Materials	
Labor	
Sub-Total	

		IV.	ELECTRICAL WORKS	
901	pcs	IV.1	110mmØ uPVC Conduit, schedule 40	
8	pcs	IV.2	Copper Clad Ground Rod 20mmØ x 3m	
47	roll	IV.3	Underground Cable Warning Tapes 3"x1000',	
			similar or better	
2613	m	IV.4	14mm <sup>2</sup> Bare Copper Wire	
4	Assy.	IV.5	Concrete Test Pit (320mm x 320mm x	
			190mm) or equivalent/better with ground rod 20mm x 3m	
1	lot	IV.6	Exothermic Mold and Powder	

Materials

Labor

Sub-Total

		V. C	CR AREA MODIFICATION		
1	lot	V.1 C	CR Area Architectural Works		
			* Window Blinds		
			* 2 x Stainless Fire-rated Door		
			* Window Heat Insulation		
2	units	V.2 2. T	.5Hp, 220~240v, 60Hz, 1Ø, Inverter, Split ype ACU including accessories		
1	lot	V.3 E	lectrical Works		
			* Conduit and Fittings		
			* Cable tray and accessories		
			* ACU copper tubing and fittings	1	1
			* ACU Circuit breaker w/ NEMA Enclosures		

Signature of Bidder's Authorized Representative

Labor

Sub-Total

		VI.	POWER, CONTROL AND MONITORING SYSTEM	
1	unit	VI.1	PAPI's Constant Current Regulator (CCR)	
			Thyristor controlled 5 KVA, 6.6 A, 220-240 VAC input, single phase, complete with the following:	
			* 5 steps brightness control	
			* Local & Remote Control, On/Off switch	
			<ul> <li>* Circuit Breaker &amp; Lightning arresters</li> <li>* Back Indication &amp; Remote Control (24- 60VDC)</li> </ul>	
			* Open circuit & Overcurrent Protection	
			<ul> <li>* Earth Fault Detector</li> <li>* Serial Mode Communication (Jbus/Mod- bus)</li> </ul>	
			* Fitting Accessories	
			* Manual in English & Schematic Diagram	
			* Equipment Nameplate	
1	unit	VI.2	Circuit Selector, complete w/back indication	
			panel complete with: * On/Off switch with Runway in Use Switch Selector * Manual/Auto Selector Switch	
1	lot	VI.3	Panel Board	
			* NEMA 1, Surface Mounted, 200A Bus, 30- Branch Circuits with Neutral Bus,	
			Ground Bus and TVSS * Main Protection: MCCB 175 AT, 225AF, 3P, 400VAC, 60Hz, 50kAIC	
			* Branch Circuits:	
			* 1 x 80AT, 1P, 230v MCCB	
			* 3 x 30AT, 1P, 230v MCCB	
			* 1 x 20AT, 1P, 230v MCCB	
			* 1 x 15AT, 1P, 230v MCCB	
			* Equipment Nameplate Note: Please refer to the reference drawing for the Panel Schedule	
50	m	VI.4	1.25 mm <sup>2</sup> x 8C Control Cable	
20	pcs	VI.5	1in Ø IMC Conduit	i i i i i i i i i i i i i i i i i i i
1	lot	VI.6	Remote Control Box	

Signat	Signature of Bidder's Authorized Representative Materials		
	Labor		
	Sub-Total		
PRECISION APPROACH PATH INDICATOR (PAPI) SYSTEM			

VII.

8	units	VII.1	PAPI Light units complete with fittings		
			accessories and:		
			* Three (3) x200W, 6.6A pre-focus halogen lamp 1000hrs		
			average rated life hours at full intensity		
			* Three (3) x core flexible cables fitted w/		
			molded two pole plugs * One (1) hardened heat resistant clear front		
			glass to protect the lenses.		
			* Three (3) x Red Filters		
			* Three (3) or Four (4) x legs fitted with		
			differential setting sleeve * Three (3) or Four (4) x Aluminum anchoring		
			legs w/ frangible couplings		
			mounted on flange and anchor bolts		
24	pcs	VII.2	Isolation Transformer, 200 watts, 6.6A/6.6A,		
			5KV, 60Hz DEB, FAA L-830 completely fitted w/		
			equipped w/ FAA I -823 connectors and plug		
			and with earthing terminal.		
8	pcs	VII.3	Primary Connector kit, 54B-E4-E4 with static l		
			lock		
8	lot	VII.4	Concrete foundation for PAPI complete w/L-		
			867 transformer base, elbows, baseplate cover,		
			fittings & accessories		
5500	m	VII.5	8mm, 5kV, Copper, Unshielded XLPE Cable		
			<ul> <li>w/ manufacturer's trademark printed throughout</li> <li>the length of cable</li> </ul>		
24	set	VII.6	Secondary connector kit 90P		
8	set	VII.7	Splicing kit		
24	pcs	VII.8	Professional Grade Rubber Tape #23,		
			19mmx6m, equivalent/better		
24	pcs	VII.9	Professional Grade Electrical Tape #33,		
			25mmx7m, equivalent/better		
30	m	VII.10	3/4in Ø Liquid Tight Flexible Conduit		
			Complete with Fittings and Accessories		
L		1		<u> </u>	<u> </u>

#### Signature of Bidder's Authorized Representative

<b>.</b>	···· <b>p</b> ······			-	
		VIII.	MISCELLANEOUS		
1	lot	VIII.1	Leveling Instruments for PAPI		
1	lot	VIII.2	Commissioning Flight Inspection of PAPI		
1	lot	VIII.3	Testing and Commissioning		
1	lot	VIII.4	In-House Training		

Materials

#### ESTIMATED DIRECT COST (EDC)

Total Materials	
Total Labor	
General Requirement	

#### Total Direct Cost:

#### ESTIMATED INDIRECT COST

Overhead (7-11 % of EDC)	
Contingencies (0.5-3% of EDC)	
Miscellaneous (0.5-1% of EDC)	
Contractor's Profit (8% of EDC)	
VAT/Contractor's Tax (5% of EDC, OCM and Profit)	
Total Indirect Cost:	

TOTAL PROJECT COST:

Signature of Bidder's Authorized Representative

# SUMMARY OF BILL OF QUANTITIES

Item	Description	Qty	Unit	Unit Price	Amount
I	General Requirements	1	lot		
II	Site Works / Delivery	1	lot		
III	Civil Works	1	lot		
IV	Electrical Works	1	lot		
V	CCR Area Modifications	1	lot		
VI	Power, Control, and Monitoring	1	lot		
	System				
VII	Precision Approach Path Indicator (PAPI) System	1	lot		
VIII	Miscellaneous	1	lot		
	<ul> <li>Nothing follows -</li> </ul>				
		[EDC + General Requirements]			
Total Indirect Cost					
TOTAL BID PRICE					

Signature of Bidder's Authorized Representative

# Section IX. Checklist of Technical and Financial Documents

# **Checklist of Technical and Financial Documents**

#### I. TECHNICAL COMPONENT ENVELOPE

#### Class "A" Documents

Legal Documents

П

☐ (a) Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages); in accordance with Section 8.5.2 of the IRR.

Technical Documents

- (b) Statement of the prospective bidder of all its ongoing government and private contracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid; and
- □ (c) Statement of the bidder's Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided under the rules; <u>and</u>
- (d) Special PCAB License in case of Joint Ventures, <u>and</u> registration for the type and cost of the contract to be bid; <u>and</u>
- (e) Original copy of Bid Security. If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission; <u>or</u> Origin al copy of Notarized Bid Securing Declaration; <u>and</u>
  - (f) Project Requirements, which shall include the following:
    - a. Organizational chart for the contract to be bid;
      - b. List of contractor's key personnel (*e.g.*, Project Manager, Project Engineers, Materials Engineers, and Foremen), to be assigned to the contract to be bid, with their complete qualification and experience data;
      - List of contractor's major equipment units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership or certification of availability of equipment from the equipment lessor/vendor for the duration of the project, as the case may be;
         and
- (g) Original duly signed Omnibus Sworn Statement (OSS); <u>and</u> if applicable, Original Notarized Secretary's Certificate in case of a corporation, partnership, or cooperative; or Original Special Power of Attorney of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder.

#### Financial Documents

☐ (h) The prospective bidder's computation of Net Financial Contracting Capacity (NFCC).

#### Class "B" Documents

(i) If applicable, duly signed joint venture agreement (JVA) in accordance with RA No. 4566 and its IRR in case the joint venture is already in existence;
 <u>or</u> duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful.

#### II. FINANCIAL COMPONENT ENVELOPE

□ (j) Original of duly signed and accomplished Financial Bid Form; and

Other documentary requirements under RA No. 9184

- $\Box$  (k) Original of duly signed Bid Prices in the Bill of Quantities; <u>and</u>
- □ (I) Duly accomplished Detailed Estimates Form (refer to Section VIII), including a summary sheet indicating the unit prices of construction materials, labor rates, and equipment rentals (refer to Annexes 2-4) used in coming up with the Bid; and
- (m) Cash Flow by Quarter (refer to Annex 5)

**NOTE:** Please refer to the Annexes provided, which include CAAP forms for items (p) and (q). Other Forms can be downloaded from the GPPB Website.



Republic of the Philippines
CIVIL AVIATION AUTHORITY OF THE PHILIPPINES

# CERTIFICATE OF SITE INSPECTION

This is to CERTIFY that [Bidder's Name/Bidder's Representative], [Position] of [Company Name], has conducted the required Site Inspection for the bidding of the project Purchase/Installation of PAPI System at San Vicente Airport.

Issued this (dd/mm/yyyy)

ANS Facility-in-Charge/ Authorized Representative

(ATTACH COMPANY LETTERHEAD/LOGO)

#### SUMMARY FOR UNIT PRICES OF MATERIALS

Project: \_\_\_\_\_\_
Location: \_\_\_\_\_

DESCRIPTION	UNIT PRICE	UNIT

SUBMITTED BY:

(ATTACH COMPANY LETTERHEAD/LOGO)

## SUMMARY FOR UNIT PRICES OF LABOR

Project:

Location:

DESCRIPTION	UNIT PRICE	UNIT

SUBMITTED BY:

Signature:	
Printed Name:	
Position:	
Name Company:	
Date:	

(ATTACH COMPANY LETTERHEAD/LOGO)

#### SUMMARY FOR UNIT PRICES OF LABOR

\_\_\_\_\_

**Project:** 

Location: \_\_\_\_\_

DESCRIPTION	UNIT PRICE	UNIT

SUBMITTED BY:

Signature:	
Printed Name:	
Position:	
Name Company:	
Date:	

{ATTACH COMPANY LETTERHEAD/LOGO}

Name of Project	
Location of Project	

# CASH FLOW BY QUARTER AND PAYMENY SCHEDULE

PARTICULAR	‰ W	1ST QUARTER	2ND QUARTER	3RD QUARTER	4TH QUARTER
ACCOMPLISHMENT					
CASH FLOW					
CUMULATIVE ACCOMPLISHMENT					
CUMULATIVE CASH FLOW					

Submitted by:

61

Name of the Representative of the Bidder

Position

Name of the Company

Date

Annex - 5

